

c/18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/NDZ/2025/ 449

Dated: 26/05/2025

To

The Principal,
Sri Guru Tegh Bahadur Girls Senior Sec. School,
Pul Bangash, Delhi - 110006.

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o Sri Guru Tegh Bahadur Girls Senior Sec. School, Pul Bangash, Delhi - 110006.

Sir,

This has reference to your letter outdoor diary no. 362 dated 08.04.2025 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on dated 17.05.2025 and observed that the shortcomings intimated vide letter of even No.F6/DFS/MS/2018/School/2062 dated 16/05/2018 (copy enclosed) have not been complied yet.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Encl: As above.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.

C/10 C/13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2018/ *School/2062*

Dated *16/05/18*

To,

The Principal,
Sri Guru Bahadur Girls Sr. School,
Pulbangash, Delhi - 110006

Sub: Regarding grant of FSC in r/o Sri Guru Bahadur Girls Sr. School,
Pulbangash, Delhi - 110006 (Gr. + Mezz. + 04 Upper floor).


Sir,

This has reference to your letter No. 86/18 dated 23/03/2018 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 28/04/2018 in the presence of Sh. Yatish Yadav (Lab Asstt.) and the following shortcomings were observed:-

1. One additional staircase to be provided.
2. Hose reel/hydrant not provided.
3. Fire pumps capacity of 450 LPM not provided.
4. Overhead water tank capacity of 10,000 liter not provided.
5. Exit signage not provided.

Hence, FSC cannot be considered at this stage.

Yours faithfully


(Sunil Chowdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director (Education),
Govt. of NCT, Old Sectt.
Delhi.