

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS /2025/SZ/ 87

Dated.../9/02/2025

FIRE SAFETY CERTIFICATE

Certified that the **Sri Sharada Institute of Indian Management Research Foundation of Jagadguru S.M.S** located at 7 Institutional Area, Phase-II, Vasant Kunj, New Delhi 110070 comprised of Basement, Ground plus Five upper floors but the Institute is running at **Ground & Two upper floors only** was issued NOC by this department vide letter no. F6/MS/DFS/2005/1122 dated 31/05/2005 for Basement, Ground plus two upper floors. The premise was re-inspected by officer concerned of this department on 31/01/2025 in presence of Mr. Soumen Datta (Director) and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building**" (for Basement, Ground plus Two upper floors) with effect from the 19/02/2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/02/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Sri Sharada Institute of Indian Management Research Foundation of Jagadguru S.M.S located at 7 Institutional Area, Phase-II, Vasant Kunj, New Delhi 110070
2. The Joint Director (S&E) Bldg, DDA Building Section, Vikas Sadan INA, New Delhi.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL-/NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
8. The occupancy above 2nd floor is not allowed till the clearance from this department.

INSPECTION REPORT

1	Name & Address of the Building	Sri Sharada Institute of Indian Management Research Foundation of Jagadguru S.M.S at 7 Institutional Area, Phase-II, Vasant Kunj, New Delhi		
2	Type of Occupancy	Mixed Occupancy		
3	Building Comprised of	Education Block, Basement, Ground + 05 upper floors & Residential Block- Ground plus two floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/2005/1122 dated 31/05/2005 for Basement, Ground plus two upper floors only.		
6	Fire Safety Directives Letter No	F6/MS/DFS/BP/2022/86 dated 14/01/2002 for Basement, Ground + 05 upper floors		
7	Date of Inspection	31/01/2025		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Soumen Datta (Director)		
10	Year of construction	2001		
11	Applicant letter No.	Outdoor diary no 11380 dated 14/01/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	09 mtr	Provided	MR
	• Gate width	6 mtr	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	01 SC G to FF	Provided	MR
	• Basement floor	02 G to Terrace		
		2 Nos + 2 ramp	Provided	MR
	b. Width of Staircase			
	• Upper floors	1.45 mtr	1.45 m, 1.45 m x 2	MR
	• Basement floor	1.45 mtr	2 x 1.45 m, 2 x 2 mtr ramp	MR
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	02	Provided	MR
	e. Width of corridor	1.5m	Provided	MR
	f. Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	20 Nos	Provided	MR
	• Types	ABC / Co2	ABC / Co2 type	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01 Nos	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Smoke & Heat	Provided	MR
		On Ground Floor	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	150 mm	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	Required	Provided	MR
		Required	Provided	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump House Access 	1620 LPM	1620 LPM	MR
		40 m	40m	MR
		02	02	MR
		180 LPM	180 LPM	MR
		40m	40m	MR
		1620 LPM	1620 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	50,000ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Ltr	20,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

m/a

19.	Fire Control Room			
	<ul style="list-style-type: none"> Detection System Panel Flow Switch Panel PA System Panel Battery backup. Building Floor plans 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20.	Special Fire Protection Systems for Protection of Special Risks, if any.	Required for HT/LT panels	Provided CO ₂ flooding system provided	MR

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

During the course of inspection it has observed that the management has been added three upper floors in the existing basement, ground plus 02 upper floors building as per the sanction building plans. Now the building is comprised of basement, ground plus 05 upper floors, but the management has applied for renewal of basement, ground plus 02 upper floors only.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/MS/DFS/2005/1122 dated 31/05/2005, renewal under rule 35 (6) of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

[Signature]
31/05/2025

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO (BCP)

DO (South)

[Signature]
14/05/25
Director

[Signature]
14/05/25

As approved, F-1. Letter in pending for your signature P1
14/05/25

[Signature]
14/05/25
Director