

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2025 / School/WZ/648

Dated 13 05 2025

FIRE SAFETY CERTIFICATE

Certified that the S.S. Saraswati Bal Mandir School located at Gali No. 1, Near Shiv Mandir, Chandpur Khurd, Delhi-110081 is running on Ground Floor only in a building comprised of Ground plus First floor was issued FSC by this department vide letter No F6 /DFS/MS/2022/School/WZ/438 dated 22.04.2022. The premises was re-inspected by the officer concerned of this department on 02.05.2025 in the presence of Sh. Pradeep Kumar (Principal), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/premise is fit for occupancy Group B Educational (for Ground floor only) with effect from ......13.05.12.25 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ... 13 95 2025. at New Delhi by

Director / Ph. 011-23414000

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054

 The Principal, S.S. Saraswati Bal Mandir School located at Gali No. 1, Near Shiv Mandir, Chandpur Khurd, Delhi-110081.

## Conditions for the validity of Fire Safety Certificate:

1. This FSC is valid for Ground floor only.

2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.

3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.

4. The trained fire fighting staff should be available round the clock.

5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.

6. This certificate cannot be treated in any case for regularizations of unauthorized construction.

7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

9. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building: S.S. Saraswati Bal Mandir School located at Chandpur Khurd, Delhi-81.

Educational

Ground plus First floor.

Renewal (for Ground Floor only)

 Name & address of the building
 Type of Occupancy
 Building Comprised of
 Type of Case
 Details of Previous NOC
 Fire Safety directives letter No F6/DFS/MS/2022/School/WZ/438 dated 22/04/2022 DOE circular No. 3298-3398 dated 01/03/2011

02/05/2025 7. Date of inspection

8. Name of Inspecting Officer R.K.Sinha, ADO (BW)

9. Name and designation of officers

Sh. Pradeep Kumar (Principal) From the building side

10. Year of Construction 2014

Outdoor Diary No. 992 dated 24/04/2025

s	11. Applicant's letter No. :	Outdoor Diary No. 992	Provided at site	Remarks		
o. No.	prevention and fire safety U/R 33	Requirement	1 Tovided at site	MR/NMR		
1.	Access to building	100 un omont				
	Road width	6 m	Provided	MR		
	Gate width	4.5 m	Directly Accessible	MR		
	Width of internal road	NA	NA	NA		
2.	Number, Width, Type & Arrangeme	nt of Exits				
	Number of staircases					
	Upper Floors	NA	NA	NA		
	Basements	NA	NA	NA		
	Width of staircases					
	Upper Floor	NA	NA	NA		
	Basements	NA	NA	NA		
	Protection of exits			- 1		
	Fire check door	NA	NA .	NA		
	Pressurization	NA	NA	NA		
	No. of continuous staircases to terrace	NA	NA	NA		
	Width of Corridor	NA	NA	NA		
	Door Size	1 m	Provided	MR		
3.	Compartmentation		795			
	Fire check door	NA	NA	NA		
	100 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	NA NA	NA NA	NA		
	Sealing of electrical shafts	35,15,97	2000			
	Fire Rating of shaft door	NA NA	NA NA	NA NA		
	Water Curtain	NA NA	NA NA	NA NA		
4	Fire Dampers Smoke Management System	NA	INA	INA		
4.			N4	N14		
	Basements	NA	NA	NA		
	Upper floors	NA	NA	NA		
5.	Fire Extinguishers					
	Total numbers	03	Provided	MR		
	Types	ABC Type	Provided	MR		
	IS marking	Required	Provided	MR		
6.	First-Aid Hose Reels	N. 1	.,,	221		
	Total numbers on each floor	NA	NA NA	NA NA		
	Length of hose reel hose	NA	NA	NA		
	Nozzle diameter	NA	NA	NA		
7.	Automatic fire detection and alarming system					
	Type of detectors	NA	NA	NA		
	Location of Main Panel	NA	NA	NA		
	Location of Repeater Panel	NA	NA	NA		
	Alternate source of power	NA	NA	NA		
	Hooters' Location	NA	NA	NA		

		NA	NA NA	NA		
8.	MOEFA	NA NA	NA NA	NA		
9.	Public Address System	NA NA		_13		
10.	Automatic Sprinkler System					
	V	NA	T NA	NA		
	Basement	NA NA	NA .	NA NA		
	Ground Floor		NA	NA		
	Sprinkler above false ceiling	NA	1111			
11.						
-	S' S - /1	NA	NA	NA		
	Size of riser/down-comer	NA NA	NA	NA		
	Number of hydrants per floor Hose Box	NA	NA	§ NA		
12.	Yard Hydrants			•		
			NA	NA		
	Total number of hydrants	NA NA	NA	NA		
	Hose Box	NA	14.2	All Control		
13.	. Pumping Arrangements					
	Ground Level		214	NA		
	Discharge of main Pump	NA NA	NA NA	NA NA		
	Head of Main pump	NA	NA			
	Number of main pumps	NA	NA	NA		
	Jockey Pump out put	NA	NA	NA		
-	Jockey pump head	NA	NA	NA		
- 1	Standby Pump out put	NA	NA	NA		
ŀ	Standby Pump Head	NA	NA	NA		
ŀ	Auto Starting/Manual Stopping	NA	NA	NA		
-		NA	NA	NA		
	Pump House Access					
	Terrace level			NA		
ľ	Discharge of pump	NA NA	NA NA	NA NA		
	Head of the pump	NA	NA	1121		
	Power Supply	NA	NA	NA		
H	Auto Starting of pump	NA '	NA	NA		
1.	Captive Water Storage for fire fighting					
	Underground tank capacity	NA	NA	NA		
		NA	NA	) NA		
100	Draw-off connection	NA	NA	NA		
	Fire service inlet	NA NA	NA	NA		
	Access to tank	NA NA	NA	NA		
	Overhead Tank capacity  Exit Signage.	NA NA	NA	NA		
-						
.   I	Provision of Lifts.					
P	ressurization of Lift Shaft	NA	NA	NA		
P	ressurization of Lift lobby	NA NA	NA NA	NA		
C	ommunication In lift Car	NA NA	NA NA	NA NA		
F	ireman's Grounding Switch	NA NA	NA NA	NA NA		
10000	ift Signage	NA NA		NA		
St	andby power supply	NA	NA	NA		
R	Refuge Area.					
To	otal Area	NA	NA	NA		
	cation	NA	NA	NA		
10.00	re Control Room					
		N/A	NA T			
Da	tector System Panel	NA NA	NA	NA		

Flow Switch Panel	NA	NA	NA
PA System Panel	NA	NA	NA
Battery backup	NA	NA	NA
Building F oor Plans	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electrical panel are installed at safer location.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2022/School/WZ/438 dated 22/04/2022.

Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation: ADO/B.W.

DCF0/.01-NW

Dated 07:05:25

13/5/202

Dencetor My

Disabor (A

SIN HOLLING

proporessi ple

13/5/2