



### FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya (Morning Shift)/ Chander Shekhar Azad Govt. Boys. Sr. Sec. School (Evening Shift) located at New Friends Colony, New Delhi – 110025, School ID No. 1925033 (Morning Shift) & School ID No. 1925005 (Evening Shift), comprised of two block : A block – Ground plus three & B block : Ground plus three was issued earlier Fire Safety Certificate vide letter No. F6/DFS/MS/School/SZ/2022/1192 dated 25/10/2022. The school building was re-inspected by the officer concerned of this department on 19/01/2026 in presence of Mrs. Indira Sagar (HOS) and overseen that all the Fire Prevention and Fire Safety arrangement provided found in good working condition. The premises have therefore deemed rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class (Group - B) “Educational Building” with effect from 02/02/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 02/02/2026 at New Delhi by.

  
(A.K. MALIK)  
Dy. Chief Fire Officer  
Delhi Fire Service  
o/c @  
30/11/26

Copy to :-

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi – 110054.
2. The Assistant Engineer (E), PWD Sub- Division M1\_PWD, Hauz Khas, New Delhi – 110016.
3. The Principal, Sarvodaya Kanya Vidyalaya (Morning Shift)/ Chander Shekhar Azad Govt. Boys. Sr. Sec. School (Evening Shift) located at New Friends Colony, New Delhi – 110025.

### Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & address of the building	Sarvodaya Kanya Vidyalaya (Morning Shift)/ Chander Shekhar Azad Govt. Boys. Sr. Sec. School (Evening Shift) located at New Friends Colony, New Delhi 110025.		
2	Building is comprised of	Comprised of 2 Block: A- block – Ground + 3 upper floors B- block – Ground + 3 upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal Case		
5	Details of previous FSC	F6/DFS/MS/School/SZ/2022/1192 dated 25/10/2022		
6	Fire safety directives letter no.	NBC PART – IV & UBBL 2016		
7	Date of inspection	19/01/2026		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/M. Road		
9	Name of the designation of officer from the building side	Mrs. Indira Sagar (HOS)		
10	Year of construction	2018 - 2019		
11	Applicant's letter no.	Email dated 26/12/2025		
S.N o	Minimum standard of fire prevention and fire safety U/R 33	Requirement AS Per NBC PART-IV & UBBL 2016	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
	A Road width	6.0 mtr.	6.0 mtr.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A Number of staircases			
	a Upper floor	03 nos each block.	03 nos each block.	MR
	c Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 mtrs each block	1.60 mtrs each block	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	02 nos each block	03 nos each block	MR
	E Width of corridor	1.50 mtrs each block	1.60 mtrs each block	MR
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	<b>Compartmentation:</b>			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

(W)

<b>5.</b>	<b>Fire Extinguisher:</b>			
	<b>A</b>	Total numbers	24 nos.	130 nos.
	<b>B</b>	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC
	<b>C</b>	ISI marking	ISI Marked	Provided
<b>6</b>	<b>First-Aid-Hose Reel:</b>			
	<b>A</b>	Total numbers of each floor	03 nos each block	03 nos each block
	<b>B</b>	Length of hose reel hose	30 m	30 m
	<b>C</b>	Nozzle diameter	05 mm	05 mm
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>			
	<b>A</b>	Type of detectors	N/A	N/A
	<b>B</b>	Location of main panel	N/A	N/A
	<b>C</b>	Location of repeater panel	N/A	N/A
	<b>D</b>	Alternate source of power	N/A	N/A
	<b>E</b>	Hooters	N/A	N/A
<b>8</b>	<b>MOEFA:</b>			
<b>9</b>	<b>Public Address System:</b>			
<b>10</b>	<b>Automatic Sprinkler System:</b>			
	<b>A</b>	Basement	N/A	N/A
	<b>B</b>	Upper floor	N/A	N/A
	<b>C</b>	Sprinkler above false ceiling	N/A	N/A
<b>11</b>	<b>Internal Hydrants:</b>			
	<b>A</b>	Size of riser/down-comer	N/A	N/A
	<b>B</b>	Number of hydrants per floor	N/A	N/A
	<b>C</b>	Hose box	N/A	N/A
<b>12</b>	<b>Yard Hydrants:</b>			
	<b>A</b>	Total number of hydrants	N/A	N/A
	<b>B</b>	Hose box	N/A	N/A
<b>13</b>	<b>Pumping Arrangements:</b>			
<b>1</b>	<b>Ground level</b>			
	<b>A</b>	Discharge of main pump	N/A	N/A
	<b>B</b>	Head of main pump	N/A	N/A
	<b>C</b>	Number of main pumps	N/A	N/A
	<b>D</b>	Jockey pump out put	N/A	N/A
	<b>E</b>	Jockey pump head	N/A	N/A
	<b>F</b>	Standby pump out put	N/A	N/A
	<b>G</b>	Standby pump head	N/A	N/A
	<b>H</b>	Auto starting /manual stopping	N/A	N/A
	<b>I</b>	Pump house access	N/A	N/A
<b>2</b>	<b>Terrace Level</b>			
	<b>A</b>	Discharge of pump	450 LPM each block	02 nos of 450 LPM each
	<b>B</b>	Head of the pump	40 m	40 m
	<b>C</b>	Power supply	Required	Provided
	<b>D</b>	Auto starting of pump	Required	Provided

<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters each block	10,000 liters each block	MR
<b>15</b>	<b>Exit Signage:</b>	N/A	N/A	N/A
<b>16</b>	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17</b>	<b>Standby Power Supply:</b>	N/A	N/A	N/A
<b>18</b>	<b>Refuge Area:</b>			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19</b>	<b>Fire Control Room:</b>			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	N/A		

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/SZ/2025/804 dated 12/11/2025 by this department has been rectified by the management.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter F6/DFS/MS/School/SZ/2022/1192 dated 25/10/2022, renewal under Rule 37 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer  
 Name Yashwant Singh Meena  
 Designation ADO/Mathura Road

20/11/26

D.O/SD

21/11/26

Dy. Secy

21/11/26  
A.K. MALIK

Principal Director

21/11/26  
A.K. MALIK

My. C.R. to D.S.

21/11/26