

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/School/2025/SZ/ 340  
To

Dated: 06/05/2025

The Principal,  
St. Anthony's Sr. Sec. School  
C-6, SDA Hauz Khas, New Delhi 110016

Sub: Regarding issuance of FSC in r/o St. Anthony's Sr. Sec. School located at C-6, SDA Hauz Khas, New Delhi 110016.

Sir,

This has reference to letter no SAS-HS/107/2025 dated 25/04/2025, received through DFS outdoor diary no 1009 dated 25/04/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 01.05.2025 in the presence of Mr. Chandan (Account) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Overhead tank capacity 5000 ltrs for Sr. block & 3000 ltrs for Pry block provided against the required capacity 10000 ltrs each block.
2. Exit signage found removed in some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54