


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/ 1172

Dated: 22/09/2025

FIRE SAFETY CERTIFICATE

Certified that the St. Bharti Public School located at 28/3A, Vikas Nagar, Rajhans Vihar, Hastal, Opp. DDA Park, New Delhi- 110059, running at ground plus two upper floors in a building comprised of ground plus three upper floors, owned/occupied by St. Bharti Public School, was issued FSC by this department vide letter No. F.6/DFS/MS/2007/1122 dated 20.04.2007 (for ground and first floor only). The school building was re-inspected by the officer concerned of this department on dated 08.09.2025 in the presence of Sh. Sarveshwar Dutt, and found that the school building have complied with fire prevention and fire safety requirements in accordance with the Rules 33 of the Delhi Fire Service Rules 2010, and that the building/ premises (ground plus two upper floors only) is fit for occupancy class B "Educational Building" with effect from 22/09/2025 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.
Issued on 22/09/2025 at New Delhi.


(Virendra Singh)
Chief Fire Officer
9cq

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.
2. The Principal, St. Bharti Public School located at 28/3A, Vikas Nagar, Rajhans Vihar, Hastal, Opp. DDA Park, New Delhi- 110059.

Conditions for validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : St. Bharti Public School at 28/3A, Vikas Nagar, Rajhans, Vihar, Hastal, Opp. DDA Park, New Delhi- 110059.
2. Building Comprised of : G+3 upper floors but school running at G+2 upper floors only
3. Type of Occupancy : Educational
4. Type of Case : New Case/ addition altration
5. Details of Previous FSC : F.6/DFS/MS/2007/1122 dated 20.04.2007 (for G+1 upper floors only)
6. Fire Safety directives letter No : N/A
7. Date of inspection : 08.09.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav (JKP)
9. Name and designation of officers
From the building side : Sh. Sarveshwar Dutt
10. Year of Construction : 2005-06 & 2015-16
11. Applicant's letter No. : Nil dated 02.09.2025

| Sr. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC/BBL Requirement | Provided at site | Remarks MR/NMR |
|---------|---|---|--|---------------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | Accessible 4.5 mtrs N/A | 06mtrs Directly accessible from road N/A | M/R MR N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floors Basements | 02 no.'s N/A | 03 No's N/A | M/R N/A |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor Basements | 1.50 & 0.75 m N/A | 1.50, 1.20 & 1.06 m N/A | M/R N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | N/A N/A | N/A N/A | N/A N/A |
| | d. No. of continuous staircases to terrace | 01 | 02 | MR |
| | e. Width of Corridor | 1.50 m | Provided | MR |
| | f. Door Size | 1.0 m | Provided | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | N/A Required | N/A Natural ventilation | N/A M/R |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 20 no's ABC/CO ₂ type ISI marked | Provided Provided ISI marked | M/R M/R M/R |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | One 30 mtrs 5 mm | Provided Provided Provided | M/R M/R M/R |

M10

| | | | | |
|-----|---|-------------|----------|-----|
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of Main Panel | N/A | N/A | N/A |
| | • Location of Repeater Panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | | | |
| 9. | Public Address System | | | |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | N/A | N/A | N/A |
| | • Ground Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey Pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting/Manual Stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 450 LPM | Provided | M/R |
| | ➤ Head of the pump | 30 mtrs | Provided | M/R |
| | ➤ Power Supply | Required | Provided | M/R |
| | ➤ Auto Starting of pump | N/A | Provided | M/R |
| 14. | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | 10,000 ltrs | Provided | M/R |
| 15. | Exit Signage. | | | |
| | | Required | Provided | M/R |
| 16. | Provision of Lifts. (No Lift) | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | | | |
| | | N/A | N/A | N/A |

| | | | | |
|-----|--|-----|-----|-----|
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | | | |
| | | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F.6/DFS/MS/2015/School/334 dated 17.02.2015 have been rectified.

Note: - Earlier, school building was issued FSC by this department vide letter No. F.6/DFS/MS/2007/1122 dated 20.04.2007 (placed at C- 11). As per undertaking submitted by Manager of the school (placed at C- 32) that the school is running their classes up to the 2nd floor only and the building constructed during the year 2004-05 (G+1 floors) and upper floors constructed in the year 2015-16. The school was recognized by MCD Education department on dated 29.11.2007.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under Rule 35 of the Delhi Fire Service Rules 2010, it's recommended to grant Fire Safety Certificate.

[Signature]
Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (South West)

[Signature]
15/9/25

CFO

[Signature]
16/9/2025

Principal Director

CFO to JKP

[Signature]
17/9/25

[Signature]
18/9

DO/SW

ADO (JKP)

[Signature]

[Signature]
18/9/2025