



11-11
C-26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/ 581

Dated: 01/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **St. Francis De Sales Sr. Sec. School** located at A-4C, Janak Puri, New Delhi-110058, comprised of two blocks namely Ist Block and IInd Block & a separate small basement. Ist Block comprised of ground floor plus two upper floors and IInd Block comprised of ground floor plus three upper floors, owned/occupied by St. Francis De Sales Sr. Sec. School was issued FSC by this department vide letter No. F.6/DFS/MS/School/2022/SZ/426 dated 19.04.2022. The school building was re-inspected by the officer concerned of this department on dated 21.04.2025 in the presence of Sh. Arun Kumar, and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building**" w.e.f. 01/05/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 01/05/2025 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
dfv.

Copy to: -

1. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi: for information regarding use of basement.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
3. The Principal, St. Francis De Sales Sr. Sec. School located at A-4C, Janak Puri, New Delhi-110058.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : St. Francis De Sales Sr. Sec. School, A-4C, Janak Puri, New Delhi
2. Building comprised of : Two blocks 1st & 2nd & a separate small basement. 1st block is having (G + 2) and 2nd block is having (G + 3). Both blocks are interconnected at each floor level.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/426 dated 19.04.2022.
6. Fire Safety directives letter No : N/A
7. Date of inspection : 21.04.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Arun Kumar
10. Year of Construction : 1978
11. Applicant's letter No. : SFS/GNCT/41/2024/DEL dated 05.03.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dated 19.04.2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible NA NA	Provided Directly accessible from road NA	MR NA NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basement 	03 No. 02 No's	06 No's 02 No's	M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.5 m .90 m	1.5 m (03 No's) in I st Blk & 1.5 m (02 No's) & 1.38 m GF to FF in II nd Blk .90 m each	M/R M/R, old case
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.5 m	2.4 m	M/R
	f. Door Size	1.0 m	1.15 m	M/R, old case
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A Sealed N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required Required	Exhaust fans Provided Natural ventilation	MR M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	38 no's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Three at each floor 30 m 5 mm	Provided Provided Provided	M/R M/R M/R


7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A		
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	M/R
	• Wooden Stage at first floor	Required	Provided	M/R
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	M/R
	• Number of hydrants per floor	three	three	M/R
	• Hose Box	three	three	M/R
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	02 no.'s Provided	M/R
	➤ Head of the pump	40 m	Provided	M/R
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	50,000 ltrs	Provided	M/R
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
			No Lift	
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

	➤ Total Area	N/A		
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2022/SZ/426 dated 19.04.2022, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note: - MP hall is located at first and second floor level 01 no. Hose reel system & Landing Valve is provided in MP hall and sprinkler system is provided over stage in MP hall.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (SW)



25/4/25



28/4/2025



29/4/25

