



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

7-  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/WZ/2025/SC/624

Dated:- 11/08/2025

To,

The Principal,  
St. Global Public School,  
C-118, Adhyapak Nagar, Nangloi,  
Delhi-110041.

**Subj.:- Regarding issuance of Fire Safety Certificate in respect of St. Global Public School, located at C-118, Adhyapak Nagar, Nangloi, Delhi-110041**

Sir,

Please refer to your letter no. SGPS/01-2025-26 dated 14/07/2025, on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department on 22/07/2025 in the presence of Sh. Manoj Yadav (Principal). During inspection, it has been observed that the school building is comprised of Ground + 01 Upper Floor. However, the following shortcoming has been observed:-

1. The width of existing single staircase is 1.10 m, against required two staircases of 1.5 m width each.
2. First – Aid Hose Reels is not provided.
3. Fire pump is not provided.
4. Overhead water storage tank of 10,000 ltrs. capacity is not provided.
5. The school management is also requested to provide approved/as built plans duly signed & stamped by Regd. Architect and signed by the owner/occupier of the building for further consideration in the matter.

In view of the above shortcomings, the application for renewal of Fire safety Certificate **cannot be considered at this stage & rejected**. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.


Yours faithfully,

  
21/8/2025

Virendra Singh  
Chief Fire Officer

Copy to:-

1. The Deputy Director, Delhi Municipal Corporation, Civic Centre, Minto Road, Delhi-110002.

  
21/8/2025