



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 52

Dated: 22/01/2025

To

The Principal,
St. Gregorios School,
Plot No, 12, Sector-11, Dwarka,
New Delhi-110075

Sub: Renewal of Fire Safety Certificate in r/o St. Gregorios School, Plot No, 12, Sector-11, Dwarka, New Delhi

Sir,

Please refer to your letter No. SGS/Admin/December/2024-25/0015 dated 23/12/2024 received through outdoor diary No. 10917 dated 02/01/2025, on the subject above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department to verify the fire safety arrangements on dated 13/01/2025 in presence of Sh. Pushpender Kumar (Admin Officer). During course of inspection, the shortcomings observed are as below.

1. Staircase to terrace found obstructed almirah and books rack.
2. Lift signage found removed.
3. IGL gas pipe-line for lab is laid through common area.
4. Door at terrace opens inwards the staircase.
5. Inspection ladder for inspection of OHWST not provided.
6. Passage connecting building blocks encroached with wooden desks.

In view of the above, the application for renewal of fire safety certificate is rejected. You are requested to rectify the shortcomings above under intimation to this department for further action. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of school management.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054