



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/291

Dated: 26/03/2025

**FIRE SAFETY CERTIFICATE**

Certified that the building of **St. Gregorios School** located at Plot No. 12, Sector-11, Dwarka, New Delhi-110075, comprised of Ground + 04 upper floors (4<sup>th</sup> Floor of the building will be used only for administrative purposes as per undertaking dated 26/03/2022), owned/occupied by St. Gregorios School, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/2022/School/383 dated 06/04/2022 (G+3 UFs only). The premise was re-inspected by the officer concerned of this department on 12/03/2025 in the presence of Sh. Pushpender Kumar (Admin Officer) and observed that school premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Rules, 2010 and that the premises/building is fit for occupancy class "**Educational Group B**" (School) with effect from 26/03/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/03/2025 at New Delhi by

(ATUL GARG)  
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Principal, St. Gregorios School at Plot No. 12, Sector-11, Dwarka, New Delhi-110075
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N-28

INSPECTION REPORT				
1.	Name & address of the building	St. Gregorios School located at Plot No. 12, Sector-11, Dwarka, New Delhi-110075		
2.	Type of Occupancy	Educational (Group-B)		
3.	Building Comprised of	Ground + 04 upper floors. (4 <sup>th</sup> Floor of the building will be used only for administrative purposes as per undertaking dated 26/03/2022 (C-52)		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/SZ/2022/School/383 Dt. 06/04/2022		
6.	Fire Safety directives Letter No.	F.6/DFS/MS/BP/2018/117 Dated 25/04/2018		
7.	Date of inspection	12/03/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Pushpender Kumar (Admin Officer)		
10.	Year of Construction	2009 & 2019		
11.	Applicant's letter No.	SGS/Admin/March/2024-25/0019 Dt. 04/03/25 Outdoor Diary No. 14042 dated 04/0/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12m	Provided	MR
	• Gate width	6m	Provided	MR
	• Width of internal road	6m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos	4 Nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 Nos	Provided	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	20 Nos	25 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02 Nos	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

88

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	100mm	Provided	MR
	• Number of hydrants per floor	02 Nos	02 Nos	MR
	• Hose Box	02 Nos	02 Nos	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	25,000 Ltr	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

N-30

19.	Fire Control Room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	CO <sub>2</sub> fire extinguisher provided near El. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F.6/DFS/MS/School/2025/SZ/52 dated 22/01/2025 found rectified.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/SZ/2022/School/383 dated 06/04/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Suman*  
20/03/25

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SW)

*[Signature]*  
24/3/25

*CFO*  
24/3/2025

*Director*

*Amr/S*

Sr, F.F. letter is put up for your sign. pr

*[Signature]*

*Suman*  
25/3/25