



c/37
OFFICE OF THE DIRECTOR
DELHI FIRE SERVICE

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/School/2025/NDZ/ 539

Dated: 24/04/2025

FIRE SAFETY CERTIFICATE

Certified that the St. John's Academy at 54/VIII, Church Road, Jawala Nagar, Shahdara, Delhi-110032, comprised of ground plus two floor only (two blocks) & basement ground plus three upper floors, owned/occupied by St. John's Academy was issued FSC vide letter No. F.6/DFS/MS/School/2022/NDZ/919 dated 30/08/2022. The school building was re-inspected by the officer concerned of this department on 16/04/2025 in the presence of Mr. Philp and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "**Educational**" (Group-B) with effect from 24/04/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on... 24/04/2025at New Delhi by.

ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/c

To,

The Principal,
St. John's Academy at 54/VIII, Church Road, Jawala Nagar, Shahdara, Delhi-110032.

Copy:-

The Dy. Director of Education,
D-Block, Anand Vihar, Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The basement is used as storage purpose only.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : St. John's Academy at 54/VIII, Church Road, Jawala Nagar, Shahdara, Delhi-110032
2. Building is comprised of : G+2 (2 blocks) and B+G+3 (one block) (All blocks are interconnected)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2022/NDZ/919 dated 30/08/2022
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 16/04/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Philp
10. Year of Construction : 1981 & 2015
11. Applicant's letter No : Letter No. nil dated 24/03/2025

| Sr. No | Minimum Standards on fire prevention and fire safety U/R33 | NBC Part-IV Requirement | Provided at Site | Remarks MR/NMR |
|--------|--|-------------------------|-------------------------------|----------------|
| 01 | Access to building. | | | |
| | • Road width | 06 mtr. | 06 mtr. | MR |
| | • Gate width | 4.50 mtr. | 4.50 mtr. | MR |
| | • Width of internal road | N/A | N/A | N/A |
| 02 | Number, Width, Type and Arrangement of Exits. | | | |
| | a. Number of Staircases | | | |
| | • Upper Floor block-A | 03 nos. | 03 nos. | MR |
| | • Upper Floor block-B | 02 nos. | 02 nos. | MR |
| | • Basement | 01 nos | 01 nos | MR |
| | B. Width of Staircases | | | |
| | • Upper Floor block-A | 1.50 mtr | 1.04 mtr, 1.25 mtr & 1.50 mtr | MR |
| | • Upper Floor block-B | 1.50 mtr | 1.20 mtr each | MR |
| | • Basement | 1.50 mtr. | 1.50 mtr. | MR |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircases to terrace | 02 nos | 03 nos | MR |
| | e. Width of Corridor | 1.50 mtr | 02 mtr to 2.10 mtr | MR |
| | f. Door Size | 01 mtr | 01 mtr | MR |
| 03 | Compartmentation. | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire rating of shaft door | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 04 | Smoke Management System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper floor | N/A | N/A | N/A |
| 05. | Fire Extinguishers. | | | |
| | • Total numbers | 40 nos. | 45 nos. | MR |
| | • Types | ABC /CO ₂ | ABC /CO ₂ | MR |
| | • IS marking | ISI marked | ISI marked | MR |

2
A

| | | | | |
|----|---|-------------|--------------|-----|
| 06 | First-aid-Hose Reels. | 03 nos. | 03 nos. | MR |
| | • Total numbers on each floor | 30 mtr. | 30 mtr. | MR |
| | • Length of hose reel hose | 05 mm | 05 mm | MR |
| | • Nozzle diameter | | | |
| 07 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of main panel | N/A | N/A | N/A |
| | • Location of repeater panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooter's location | N/A | N/A | N/A |
| 08 | MOEFA | N/A | N/A | N/A |
| 09 | Public address System. | | | |
| 10 | Automatic Sprinkler System. | | | |
| | | Required | Provided | MR |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | | | |
| 11 | Internal Hydrants | | | |
| | • size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | | | |
| | ➤ Ground Level | N/A | N/A | N/A |
| | • Discharge of main Pump | N/A | N/A | N/A |
| | • Head of Main Pump | N/A | N/A | N/A |
| | • Number of main pumps | N/A | N/A | N/A |
| | • Jockey pump out put | N/A | N/A | N/A |
| | • Jockey pump head | N/A | N/A | N/A |
| | • Standby pump out put | N/A | N/A | N/A |
| | • Standby pump Head | N/A | N/A | N/A |
| | • Auto Starting /Manual stopping | N/A | N/A | N/A |
| | • Pump House Access | N/A | N/A | N/A |
| | ➤ Terrace Level | | | |
| | • Discharge of pump | 3 x 450 LPM | 3 x 450 LPM | MR |
| | • Head of the Pump | 40 m | 40 m | MR |
| | • Power supply | Required | Provided | MR |
| | • Auto Starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | • Draw-off connection | N/A | N/A | N/A |
| | • Fire service inlet | N/A | N/A | N/A |
| | • Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | 20,000 ltr. | 20,000 ltr. | MR |
| 15 | Exit Signage. | Required | Not Provided | MR |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |

✓

| | | | | |
|----|--|-----|-----|-----|
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule the FSC issued vide letter no. F.6/DFS/MS/School/2022/NDZ/919 dated 30/08/2022 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
16/04/2025
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O

~~DO(ED)~~ DFA Please.

By C.F.O./NDZ

Deepak
16/04/2025

Kirp
17/04/25

C.F.O./
17/4/2025

Director
17/4/25

And/SHD

Sir, for letter put up for your
kind signature pl.

Deepak
23/04/2025

Director