



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

C34  
75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/WZ/School/2025/ 794

Dated:- 17/06/2025

**FIRE SAFETY CERTIFICATE**

Certified that the St. Kabir Modern School, Located at Uday Vihar, Part-III, Nilothi, Delhi-110041, running in one block comprised of Ground + 01 Upper Floor only in a building is comprised of 02 blocks – ground + 01 upper floors, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/WZ/2022/470 dated 28/04/2022. The said premise was re-inspected by the officer concerned of this department on 27/05/2025 in the presence of Ms. Jaspreet Kaur (Principal) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17/01/2005 and that the school building is fit for occupancy class “Educational Building” Group B” with effect from 17/06/2025 for a period of three years, subject to compliance of the conditions, printed below.

Issued on 17/06/2025 at New Delhi by

(Atul Garg)  
Director

Tel. No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, St. Kabir Modern School, Uday Vihar Part-III, Nilothi, Delhi-110041.

**Conditions for validity of fire safety certificate :-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in ‘Form J’ (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name and address of the building: St. Kabir Modern School, located at Uday Vihar Part-III, Nilothi, Delhi-110041
2. Type of Occupancy : Educational (G + 01 Upper Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2022/470 dated 28/04/2022
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 262-362 dated 17/01/2005
6. Date of inspection : 27/05/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Ms. Jaspreet Kaur (Principal)
9. Year of Construction : 2005
10. Applicant's letter No. : email dated 03/04/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cr. No. 262-362 dated 17/01/2005/ as per earlier FSC issued dated 28/04/2022	Provided at site	Remarks MR/NMR
1.	Access of building			MR
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02	Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 m each	1.5 m x 2	MR
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1.0 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	08 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• ISI marking	ISI Marked	Provided	MR



6.	First – Aid Hose Reel		Provided	MR
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system		NA	NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System		NA	NA
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:		NA	NA
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants		NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:		NA	NA
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	220 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:		NA	NA
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 262-362 dated 17/01/2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2022/470 dated 28/04/2022 is recommended.

Accordingly DFA is prepared for approval & signature please.

*[Signature]*  
29/05/25  
Aman Kumar Lathar  
ADO (JWP)

*[Signature]*

*[Signature]*  
9/6/2025

SD  
[Stamp]

Cfo/  
*[Signature]*  
10/6/2025  
Director  
*[Signature]*  
11/06/25

*[Signature]*

Sir,  
F.T. letter is put-up for your signature pl.

*[Signature]*  
*[Signature]*

*[Signature]*  
13/06/25  
Aman (JWP)