



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/ 701

Dated: 09/09/2025

To

The Manager,
St. Louis Public School,
RZ-50 A, Hari Vihar,
Palam More, New Delhi-110078

Sub: Renewal of Fire Safety Certificate in r/o St. Louis Public School at RZ-50 A, Hari Vihar, Palam More, New Delhi-110078.

Sir,

This has reference to your letter No. S.L.P.S/2025 dated 01/08/2025, received in this department vide outdoor diary No. 4451 dated 01/08/2025. In this connection, the premise was inspected by the officer concerned of this department on 25/08/2025 in your presence. During the inspection, it was observed that the school management is using second floor of the building for school activities. Accordingly, the shortcomings observed are as below.

1. One of the staircases found blocked at first floor.
2. The fire extinguishers provided found insufficient, two fire extinguisher (ABC or CO₂) shall be required at each floor.
3. One hose-reel at each floor connected to overhead water storage tank of 10,000 liters capacity exclusively for firefighting, through a terrace pump of 450 LPM discharge capacity with 40-meter head not found provided.
4. Exit signage found not provided at appropriate locations in the escape route.

In view of the above shortcomings, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054