



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/637

Dated: 11/08/2025

To

The Principal
St. Margaret School
B-Block, Derawal Nagar, Delhi-09

Sub: - Regarding grant of fire safety certificate in r/o St. Margaret School located at B-Block, Derawal Nagar, Delhi-110009.

Sir,

Please refer to your letter no- SMS/DW/2025/323 dated: 01/07/2025 received in this department vide outdoor dairy no-3289 dated 02/07/2025 on the subject cited above. In this connection this is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 09/07/2025 in the presence of Smt. Meetu Mehra (Principal) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school building is comprised of 03 blocks, 02 blocks comprised of ground floor & 01 block comprised of basement, ground & first floor only. The observations/ shortcomings made are as under:-

1. There is only one staircase is provided width of 1.25m against the requirement of 1.50m if travel distance meets otherwise additional staircase of 75m.
2. Fire check door is not provided in the basement.
3. Sprinklers system is not provided in basement.
4. Terrace level fire pump capacity of 450 LPM is not provided.
5. Terrace level fire fighting water tank capacity of 5,000ltr is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully


5/8/2025
Virendra Singh
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of Delhi, Zone-IX, District North West-A, Shalimar Bagh, BL- Block, Delhi- 110088.