



27  
27

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. F6/DFS/MS/School/2025/NDZ/ 1124

Dated: 10/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that the St. Mark Sr. Sec Public School located at Lal Madir Road, Harsh Vihar, Delhi-110093, comprised of Ground plus three upper floors, owned/occupied by St. Mark Sr. Sec Public School was issued FSC vide letter No. F.6/DFS/MS/School/2022/NDZ/483 dated 02/05/2022. The premises was re-inspected by the officer concerned of this department on 25/08/2025 in the presence Mrs. Suman Singh, Principal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" (Group-B) with effect from 10/09/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010& also conditions printed below.

Issued on.....10/09/2025.....at New Delhi by.

Virendra Singh  
9/9/2025

(VIRENDRA SINGH)

o/c 2. CHIEF FIRE OFFICER

To,

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053
2. The Principal, St. Mark Sr. Sec Public School located at Lal Madir Road, Harsh Vihar, Delhi-110093

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : St. Mark Sr. Sec. Public School  
Lal Madir Road, Harsh Vihar, Delhi-110093
2. Building is comprised of : Ground plus three upper floors only
3. Type of Occupancy : Educational, Group-B
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2022/NDZ/483 dt 02/05/2022
6. Fire Safety direction letter No. : NBC Part IV
7. Date of Inspection : 25/08/2025
8. Name of the Inspecting officers : ADO Deepak Kumar
9. Name and designation of Officer  
from the building side : Mrs. Suman Singh, Principal
10. Year of Construction : 2004
11. Applicant's letter No : Outdoor diary No. 4251 dated 28/07/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMF
01	Access to building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06mtr. N/A N/A	06 mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	01 nos.	03 nos.	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basement</li> </ul>	N/A	N/A	N/A
	B. Width of Staircases	1.50 m	1.80 m, 1.90 m & 1.50 m up to 1 <sup>st</sup> floor	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basement</li> </ul>	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01 nos.	02 nos.	MR
	e. Width of Corridor	1.50 m	1.50 m	MR
	f. Door Size	01m	01m to 1.20 m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire rating of shaft door</li> <li>Water curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floor</li> </ul>	N/A N/A	N/A N/A	N/A N/A



05.	Fire Extinguishers			
		20 nos.	25 nos.	MR
	• Total numbers	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• Types	ISI marked	ISI marked	MR
	• IS marking			
06	First-aid-Hose Reels.			
	Total numbers on each floor	01 no	01 no.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace Level			
	➤ Discharge of pump	450 lpm	450 lpm	MR
	➤ Head of the Pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The earlier shortcomings issued vide letter no. F.6/DFS/MS/School/NDZ/2025/538 dated 20/06/2025 have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, the FSC issued vide letter no. F.6/DFS/MS/School/2022/NDZ/852 dated 04/08/2022 **renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.**

*Deepak*  
26/08/2025  
Signature of the Inspecting Officer  
Name :- Deepak Kumar  
Designation :- A.D.O (Shd)

DO (ED) *Ad*  
27.08.2025  
by C.F.O (NSZ) *King*  
27/08/25  
C.F.O *King*  
28/08/2025  
Principal Director  
C.F.O to *King*  
29/08/25