



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2025/WZ/866

Dated: 03/12/2025

To,

The Principal,
St. Mark's World School,
A-Block, Meera Bagh,
Delhi-110087.

Sub:- Renewal of Fire Safety Certificate in respect of St. Mark's World School located at Shiv Ram Park, A-Block, Meera Bagh, Delhi- 110087.

Sir,


This has reference to your Form J received through outdoor diary no. 7904 dated 06/11/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 19.11.2025 to see the compliance of the requisite fire safety measures. Ms. Sheena Kalenga (Principal) was present at the time of inspection.

During the course of inspection it was observed that the school building is comprised of Ground and Three upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Smoke ventilation system in audi found removed.
2. Smoke detectors in audi found provided but not functional.
3. MOEFA found provided but not functional.
4. Terrace level pump not found in auto mode.
5. Exit signages found removed at some places.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully


03/12/25

(S.K. Dua)

Dy. Chief Fire Officer
West Zone



Copy to :-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.