

2144

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/School/2025/ 36

Dated: 15 / 01 / 2025

To

Sh. Jose Joseph,  
St. Michael's Junior School,  
Prasad Nagar, New Delhi.

**Sub: Regarding issuance of FSC in r/o St. Michael's Junior School, Prasad Nagar, New Delhi.**

Sir,

This has reference to your letter no. nil dated 30/11/2024, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 06.01.2025 in the presence of Sh. Jose Joseph and following shortcomings are observed.

1. Sprinkler is provided partially in the basement, required to be extended in left out area not provided.
2. 02no. of terrace pump of 450 LPM is required, whereas 01 pump of 450 LPM is provided.
3. Exit signages are not provided.
4. Basement is being used for auditorium, sanctioned plan is required to be submitted to verify the occupancy in the basement.

In view of above, fire safety certificate (FSC) cannot be issued at this stage. Therefore, you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.