

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/2025/ School/ 10/

Dated: 31/01/2025

**FIRE SAFETY CERTIFICATE**

Certified that the St. Michael's Sr. Sec. School, no.3, Pusa Road, New Delhi comprises of Ground + 02 Upper floors, was earlier granted FSC by this department vide letter No. F6/DFS/MS/School/SZ/2022/257 dated 10/03/2022. Now, the premises was re-inspected by the officer concerned of this department on 23/01/25 in the presence of the Mis IDA & Mr. Paul, Teacher and found that school has deemed complied with the fire prevention and fire safety requirements in accordance with circular of Director of education dated 17/01/2005 and the premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from .....31.01. 2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on .....31.01/2025 at New Delhi by.

(Atul Garg)  
 DIRECTOR  
 Delhi Fire Service

Copy to:-

1. The Commissioner , MCD , Civic Centre , New Delhi
2. Director of Education, Govt. of NCT, Delhi.
3. The Principal, St. Michael's Sr. Sec. School, no.3, Pusa Road, New Delhi.

**Conditions for the validity of fire safety certificate**

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. Any flammable material for interior decoration shall strictly prohibited.



INSPECTION REPORT

1. Name & address of the building:- St. Michael's Sr. Sec. School, no.3, Pusa Road, New Delhi
2. Type of occupancy:- Educational Group B-I, Gr. + 02 Upper floors,
3. Type of case:- renewal
4. Details of previous FSC:- F6/DFS/MS/School/SZ/2022/257 dated 10/03/2022
5. Fire safety directives No.- N/A
6. Date of inspection:- 23/01/2025.
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Mis. IDA & Mr. Paul, teacher
9. Year of construction:- 1980
10. Applicant's letter No:- letter no. nil dated 11.12.2024.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per FSC dated 02.04.2019	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Accessible	12 mtr.	MR
	2) Gate width	4.8 m	provided	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03	03	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50, 1.38 m & 1.28 m	1.50, 1.38 m & 1.28 m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	03	03	MR
	E. Width of corridor	2.8 m	2.8 m	MR
	F. Door size	Required	90 cm & 1.2 m	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	sealed	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Required	Natural Vent.	MR
5.	Fire Extinguishers			
	1) Total numbers	04 Nos. at each floor	Provided	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR



N/37

	3) ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	03 nos.	03 nos.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			MR
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 m	100 m	N/A
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level	01 no.	01 no.	MR
	a) Discharge of pump	450 LPM	provided	MR
	b) Head of pump	30 mtr.	40 m each	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A

W/34

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	Required	02 ABC type fire extinguishers provided near elect. Panel	MR.

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/School/SZ/2022/257 dated 10/03/2022, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer



Name :- Rayinder Singh  
Designation :- ADO (CC)

  
28/1/25  
Director



