



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 1089

Dated: 02/09/2025

FIRE SAFETY CERTIFICATE

Certified that the St. Model Public School located at I-21, Mahendra Park, Near Adarsh Nagar, Delhi-110033 comprised of Ground & 03 upper floor owned/ occupied by St. Model Public School was issued Fire Safety Certificated by this department vide letter No. F6/DFS/MS/2022/School/1175 Dated: 21/10/2022. The premises was inspected by the officer concerned of this department on 21/08/2025 in presence of Sh. Harvinder Singh (President) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premises is "fit for occupancy class Group B Educational (School)" with effect from02/09/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on02/09/2025 at New Delhi by.

Virendra Singh
Chief Fire officer
Delhi Fire Service

Copy to: -

1. The Dy. Director, Education Department, Civil Line Zone, MCD, 16, Rajpura Road, Delhi.
2. The President, St. Model Public School located at I-21, Mahendra Park, Near Adarsh Nagar, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : St. Model Public School at I-21, Mahendra Park, Near Adarsh Nagar, Delhi-33.
2. Type of Occupancy : Educational
3. Composition of building : Ground & 03 Upper floors only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2022/School/1175 Dated: 21/10/2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 21/08/2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Harvinder Singh (President)
10. Year of Construction : 1980
11. Applicant's letter No. : Online E-mail Dated- 29/07/2025


S.No	Minimum Standards on fire prevention and fire safety U/R 33	D. O. E Circular Dated 01/03/2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m & 1m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	01m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	05nos	06nos	MR
	• Types	ABC/CO2	ABC-06	MR
	• ISI marking	ISI Marked	Yes	MR

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none">• Total numbers on each floor• Length of hose reel hose• Nozzle diameter	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	Autómatic fire detection and alarming system.			
	<ul style="list-style-type: none">• Type of detectors• Location of Main Panel• Location of Repeater Panel• Alternate source of power• Hooters' Location	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none">• Basement• Upper Floor• Sprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		N/A	NA	N/A
		14	Captive Water Storage for fire fighting.	
<ul style="list-style-type: none">• Underground tank capacity<ul style="list-style-type: none">➤ Draw-off connection➤ Fire service inlet➤ Access to tank• Overhead Tank capacity	NA		NA	NA
	NA		NA	NA
	NA		NA	NA
	NA		NA	NA
	10,000 LTR		Provided	MR
	15		Exit Signage.	Required


16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.


Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is **recommended for renewal of fire safety certificate** issued vide this department letter of even no. F6/DFS/MS/2022/School/1175 Dated: 21/10/2022.



 Signature of the Inspecting Officer
 Name :-C.L. Meena
 Designation:- ADO/RN


D.B. Mukharjee (DO/NW)


 25/08/2025
 Dy. CEO (NW)


 26/8


 27/8/2025
 Principal Director


 28/08/25


 29/8/2025

A DO(RN)

DCFO/...244/1175
 Date: 21/8/2025