

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/102

Dated: 03/02/2025

FIRE SAFETY CERTIFICATE

Certified that the **St. Paul's School**, located at **Phase- VI, H- Block, Aya Nagar, New Delhi- 110047** comprised of Basement, Ground plus Two upper floors owner/occupied by **St. Paul's School** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2021/SZ/340 dated 22/04/2021. The premise was re-inspected by officer concerned of this department on 21/01/2025 in presence of Mr. Shaji (Caretaker) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **"Educational Building Group - B"** with effect from 03/02/2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 03/02/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. St. Paul's School, located at Phase- VI, H- Block, Aya Nagar, New Delhi- 110047
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept unlocked and free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL-/NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

15

INSPECTION REPORT

1	Name & Address of the Building	St. Paul's School at Phase-VI, H-Block, Aya Nagar, New Delhi-110047		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement + Ground + 2 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2021/SZ/340 dated 22/04/2021		
6	Fire Safety Directives Letter No	NBC / UBBL - 2016		
7	Date of Inspection	21.01.2025		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Shaji (Caretaker)		
10	Year of construction	2020		
11	Applicant letter No.	Email dated 18-11-2024		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL / NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	9 mtr	MR
	• Gate width	Required	4 mtr	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	➤ Upper floors.	2 Nos	2 Nos	MR
	➤ Basement floor.	2 Nos	2 Nos	MR
	b. Width of Staircase			
	➤ Upper floors	1.5 mtr. Each	2.50 m each	MR
	➤ Basement floor	1.5 mtr. Each	2.50 m each	MR
	c. Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	Required	Two	MR
	e. Width of corridor	1.5 mtr	2.5 mtr	MR
	f. Door size	1.20 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	12 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	18 Nos	Provided	MR
	• Types	ABC / Co2	ABC- 18	MR
	• ISI Marking	Required	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	02 No	02 Nos	MR
	• Length of hose-reel hose.	30 mtr	provided	MR
	• Nozzle Diameter	5 mm	provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	NA	NA	NA


	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	NA	NA	NA
		NA	NA	NA
13.	Pumping arrangements.			
	A. Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting / Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	B. Terrace Level			
	➤ Discharge of pump.	900 LPM	Provided	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		15,000 Ltr	20,000 ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	NA	NA	NA

• Flow switch panel.	NA	NA	NA
• PA system panel.	NA	NA	NA
• Battery backup.	NA	NA	NA
• Building floor plan.	NA	NA	NA
20. Special Fire Protection System for the Protection of special Risk, if any.	NA		




The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2021/SZ/340 dated 22/04/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspection Officer
 Name: Sh. Rajesh Kumar
 Design: ADO (BCP)

DO (South)

 28/1/25
 CPO/(RDB)
 30/01/2025
 Director
 30/1/25
 AMR/51.0

As approved, F.T. letter is pending for your signature P1


 Director
 31/1/25
 m


 31/01/2025