

e-65

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/2025/ School/ 997

Dated: 13/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the St. Thomas School at Mandir Marg, New Delhi having two blocks namely Admin block (ground + 1 floor )& library block( gr. + 3 upper floor ) both block connected at first floor. The FSC was granted by this department vide letter No. F6/DFS/MS/2010/2950 dated 13.10.2010 for admin block only. Now, the premises was re-inspected by the officers concerned of this department on 23/07/25 in the presence of Mr. S. Panda & Mr. Emanuel and found that the said building blocks have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class Group B "Educational Building with effect from 13/08/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on ...13/08/2025..... at New Delhi by.

  
 12/8/2025  
 (Virendra Singh)  
 Chief Fire Officer  
 Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
3. The Principal, St Thomas School Mandir Marg, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Basement if any shall be used as per NBC/BBL 1983.
6. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
9. Any flammable material for interior decoration shall strictly prohibited.

4/18  
**INSPECTION REPORT**

1.	Name & address of the building	St. Thomas Girls Sr. Secondary School, at Mandir Marg, New Delhi.
2.	Type of occupancy: -	Educational group -B Admin block ( Gr. plus first floor ) , Library Block ( G plus three floor )
3	Type of case: -	Renewal
4	Details of previous FSC: -	<u>F.6/DFS/MS/2010/2950 dated 13.10.2010( Admin block &amp; Middle block )</u>
5	Fire safety directives No.-	Director of education circular no. F16/Estate/CC/Fire safety 2011/3298-3398 dated 01.03.2011
6	Date of inspection: -	23.07.2025
7	Name of the inspecting officer: -	Sh. Ravinder Singh (ADO/CC) Sh. Rajinder Atwal , DO ( CD)
8	Name & designation of officer From the building side: -	<u>Mr S. Panda and Mr. Emmanuel</u>
9	Year of construction: -	1934 & 2000
10	Applicant's letter No: -	letter no. nil dated 23.06.2025& DFS diary no. 2953 (A) dated 23.06.2025.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	06mtr	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	Upper floor a. admin block	01 of 1.5 m or 02 of any <del>length</del> width	02 nos	MR
	b. library block	01 of 1.5 m or 02 of any <del>length</del> width	01 nos	MR
	Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	Upper floors a. admin block	1.50 & 1.32 m	1.50 & 1.32 m	MR
	b. library block	1.5 m	1.5 m	MR
	Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous</b>	N/A	N/A	N/A



M/119

	staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01m	Provided	MR
3.	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	<b>Fire Extinguishers</b>			
	1) Total numbers	16 Nos.	Provided	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	<b>First-Aid Hose Reel ( library block )</b>			
	1) Total number at each floor	01 nos	01nos	MR
	2) Length of hose reel hose	30mtr	30mtr	MR
	3) Nozzle diameter	05mm	Provided	MR
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer( library block )m	100mm	Provided in library	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	Required	Provided	MR
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	1620 LPM	MR
	b) Head of main pump	N/A	40mtr	N/A
	c) Number of main pump	N/A	02nos	N/A
	d) Jockey pump out put	N/A	180 LPM	N/A
	e) Jockey pump head	N/A	40mtr	N/A
	f) Stand by pump output	N/A	1620 LPM	N/A
	g) Stand by pump head	N/A	40mtr	N/A
	h) Auto starting/Manual stopping	N/A		N/A
	2) Terrace level			

M/20

	a) Discharge of pump	450 lpm	Provided	MR
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	50,000 liter	50,000liter	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 liter	10,000 liter	MR
15.	Exit Signage.	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any: ABC &amp; CO<sup>2</sup></b>			

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.  
In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/2010/School/2950 dated 13/10/2010, under Rule 35(6) of the Delhi Fire Service rules 2010, is recommended for approval

Signature of the Inspecting Officer

Name :- Rajinder Atwal  
Designation :- DO (CD)

Signature of the Inspecting Officer

Name :- Ravinder Singh  
Designation :- ADO (CC)

*[Signature]*  
C.F.O.  
Principal Director  
4/8/2015

CFO to Secy.

*[Signature]*  
CFO

*[Signature]*  
27/08/2015

Asst Key

*[Signature]*  
11/8/2015

DP