

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2025/SZ/ 17
To

Dated: 09/01/2025

M/s STAGEDOOR Auditorium & Theatre Academy,
A-5, Saket District Centre, Saket,
NEW Delhi 110017

Sub: Regarding issuance of FSC in r/o M/s STAGEDOOR Auditorium & Theatre Academy, A-5, Saket District Centre, Saket, New Delhi 110017

Sir,

This has reference with your letter no nil dated 26/12/2024 received through outdoor diary no 10803 dated 27/12/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03.01.2025 in the presence of Mr. Ram Babu to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors found removed in the building.
2. Smoke management system in basement found removed.
3. First aid hose reel provided but found non- functional.
4. Automatic detection system provided but found non- functional.
5. MOEFA provided but found not working.
6. Automatic Sprinkler System provided but found non- functional.
7. Internal hydrant and yard hydrant provided but found non- functional.
8. Electrical Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM provided but found non- functional.
9. Exit Signage found removed at some places.
10. The pressurization of staircase & lift lobbies not working.
11. Standby power supply not working.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/Management.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint Director (Bldg) DDA, INA, New Delhi 110003.