

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/GH/2025/NDZ/194

Dated: 23/04/2025

To,

The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi

**Subject: -Regarding renewal of Fire Safety Certificate in r/o M/s Standard Guest House, situated at
17, N.S. Marg, Darya Ganj, Delhi.**

Sir,

This is in reference to MCD online portal ID. 2025032504534, Dated- 25/03/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned guest house from fire safety point of view in presence of Mr. Vinod Kapoor on dated 19/04/2025. The building comprised of Ground + Mezzanine + 03 upper floors. The following shortcomings were observed during the time of inspection.

1. First Aid Hose reel provided but not functional.
2. A terrace pump capacity 450 lpm head 40 meters provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE