



c/113



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F.6/DFS/MS/Banquet/NDZ/2025/ 97

Dated: 03/06/25

To,

The Joint Commissioner (Lic.)  
1<sup>st</sup> floor Police Station Defence Colony,  
New Delhi

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Starland Gold (A Unit of MGH Hospitality Pvt Ltd.) located at B-07, G. T. Karnal Road Industrial Area, New Delhi- 110033.**

Sir,

This has reference to MCD application ID No. 2025050107664, Dated- 01/05/2022 on the subject cited above. In this connection, the premises was re-inspected by the officer concerned of this department on dated 26/05/2025 of the above mentioned Banquet Hall from fire safety point of view in presence of Mr. Rajeev Nagpal, Owner. The Banquet Hall building comprised of ground plus two upper floors. The following shortcoming was observed during the time of inspection.

1. Fire Check doors are not provided.
2. Electric shaft is not sealed.
3. Two hours fire resistance rating shaft door are not provided.
4. MOEFA provided but not functional.
5. A standby pump is not provided.
6. Pressurization of lift shaft and lift lobby are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

9-2

30/6