

C/48

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/EH/SZ/2025/165

Dated: 17 / 04 / 2025

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Stay White Café Pvt. Ltd. at Prop. No. 32, 3rd Floor, Link Road, Lajpat Nagar-III, New Delhi - 110024.

Sir,

This has reference to online application ID No. 2025032104182 dated 21.03.2025 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.04.2025 in presence of Mr. Manjil (Manager) and it was observed that building is comprised of Basement + Stilt + Ground + 03 upper floors + extended mummy on terrace. During inspection, following shortcomings were observed:

1. Fire extinguishers provided but non functional.
2. MOEFA provided but not functional.
3. Fire pump not in auto start mode.
4. Exit signages are not adequately provided.
5. Exit routes found encroached with almirahs.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel: 01123414000
e 16/4

Copy to:-

The Manager,
M/s Stay White Café Pvt. Ltd. at Prop. No. 32, 3rd Floor, Link Road, Lajpat Nagar-III, New Delhi - 110024.