

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
NO. F-6/DFS/MS/EH/2025/SZ/341

Dated 18/08/2025

To

The Commissioner,
Municipal Corporation of Delhi,
E-1, 9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi-110002

Sub: - Regarding issuance of fire safety certificate in r/o M/s Subway (A Unit of Eversub India Pvt Ltd) located at Shop No 4, Ground Floor, Aggarwal Plaza, Plot No 11, Sector 12, Dwarka, Delhi 110075.


Sir,

This has reference with **MCD Portal ID 2025071911592 dated 21/07/2025** on the subject cited above. In this connection, this is to inform you that the above-mentioned premise was visited by the officer concerned of this department on 05.08.2025 in the presence of Ms. Divya (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations: -

- 1 There is one exit door having width of 1.25 mtr against the required two exit door having width of 1.50 each.
- 2 First aid hose reel hose not provided.
- 3 MOEFA not provided.
- 4 Internal hydrant not provided.
- 5 Terrace level firefighting pump capacity of 450 LPM Not provided.
- 6 Overhead tank capacity 20,000 ltrs not provided.
- 7 Exit signages not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

