



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

Dated: 21/01/2025

No. F6/DFS/MS/School/NDZ/2025/ 48

To,

The Principal,
Sugam Public School
E - 43, Gali No. 15, Madhu Vihar,
Delhi - 110092.

Subject: - Regarding grant of Fire Safety Certificate in r/o Sugam Public School located at E - 43, Gali No. 15, Madhu Vihar, Delhi - 110092.

Sir,

This has a reference to your Outdoor Dairy No. 9364 dated 20.11.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 10/01/2025 in the presence of Mr. K.K. Sharma (Manager) and observed that building comprised of basement (Store) + ground + four upper floors (School is running on G + 2 upper floors only),

Following shortcomings were observed during time of inspection:

1. One Staircase of width 0.90 mtr. not found connected to second floor.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 220 LPM provided but not functional.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

OK (w) DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, Department of Education, MCD, Distt. North East, Shahdara, Delhi.
2. The Manager, Sugam Public School located at E-43, Gali No. 15, Madhu Vihar, Delhi - 110092.