



No. F6/DFS/MS/SCHOOL/NDZ/2025/679

Dated: 21/05/2025

FIRE SAFETY CERTIFICATE

Certified that **Sugam Public School** located at **E - 43, Gali No. 15, Madhu Vihar, Delhi - 110092**, Building comprised of basement (Store), ground plus four upper floors (School is running on Ground + 2 upper floors only, 3rd floor (Vacant not in use), 4th floor (Sealed) owned / occupied by **Sugam Public School**, was issued Fire Safety Certificate vide letter No F6/DFS/MS/2006/3361 dated 16/11/2006. The school building was re-inspected by the officer concerned of this department on 09/05/2025 in presence of Mr. K.K. Sharma (Manager) and observed that all the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 issued by Director of Education and that the building is fit for occupancy class (Group - B) **"Educational Building"** for **ground plus two upper floor only** with effect from 21/05/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 21/05/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The commissioner, MCD, Civic Centre, New Delhi- to ensure the occupancy as detailed above & deviation, if any.
2. The Director of Education, Municipal Corporation of Delhi, 419 Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.
3. The Principal, Sugam Public School located at E -43, Gali No.15, Madhu Vihar, Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. **Fire Safety Certificate is valid for ground plus two upper floors only.**
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. At the time of inspection basement is being used for storage purpose only.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Sugam Public School located at E - 43, Gali No.15, Madhu Vihar, Delhi – 110092.		
2	Building is comprised of	Basement (Store), Ground floor (School), 1 st floor (School), 2 nd floor (School), 3 rd floor (Vacant) & 4 th floor (Sealed).		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/2006/3361 dated 16/11/2006		
6	Fire safety directives letter no.	Circular No. 262-362 dated 17/01/2005		
7	Date of inspection	09/05/2025		
8	Name of the inspecting officers	Yashwant Singh Meena ADO, Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. K.K. Sharma (Manager)		
10	Year of construction	2005		
11	Applicant's letter no.	Outdoor diary no. 1141 dated 29/04/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 meters.	6.0 meters.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 no.	02 no.	MR (Old Case)
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.5 meters.	1.05 meters & 0.90 meter	MR (Old case)
	b Basement	N/A	2.50 meters	MR
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no.	01 no.	MR
	E Width of corridor	1.25 mtrs.	1.25 mtrs.	MR
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

(W) A

Sugam Public School located at E-43, Gali No.15, Madhu Vihar, Delhi – 110092.


5.	Fire Extinguisher:				
	A	Total numbers	06 nos.	15 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 mtr.	30 mtr.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	220 LPM	220 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	2,500 liters.	Provided	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	N/A	N/A	N/A
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Note: - At the time of inspection basement is being used for storage purpose only, third floor vacant and fourth floor is permanently closed and hence not in use. (As per undertaking and photo enclosed).


The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. The shortcoming issued by this department vide letter No. F6/DFS/MS/School/NDZ/2025/48 dated 21/01/2025 has been rectified.


Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/2006/3361 dated 16/11/2006, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.



16/05/2025


Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO/Laxmi Nagar


D.O/EAST DFA please.


13/05/2025


14/05/25


16/05/2025


17/05/25


18/05/25