

251

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

NO.F.6/DFS/MS/FH/2026/ 301

Dated: 9/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Center, Minto Road,
New Delhi-110002.

Sub: - Reply of application regarding FSC/NOC in r/o M/s Summer House Cafe, (A Unit of Shaktiraj Hospitality Pvt Ltd.) located at First Floor, DDA Shopping Complex, Aurobindo Place Market, Hauz Khas, New Delhi - 110016.

Sir,

This has a reference to Online Portal I.D. **2026030902545 Dt. 09/03/2026** on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 25/03/2026 in the presence of Mr. Manish Sharma (Manager). During course of inspection, the shortcomings observed are as below: -

1. Hose reel/ Internal hydrant found non- functional.
2. MOEFA found non-functional.
3. Automatic sprinkler system found non-functional.
4. Terrace pump found non-functional.
5. Auto starting of terrace pump found non-functional.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of owner/occupier of the establishment. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
