



c/57



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F6/DFS/MS/EH/SZ/2026/442

Dated: 06/05/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s. Summer House Café (A unit of Shaktiraj Hospitality Pvt. Ltd.), located at 1st Floor, DDA Shopping Complex, Aurobindo Palace, Hauz Khas, New Delhi-110016, in the building comprised of ground and first floor only, Owned/Occupied by (A unit of Shaktiraj Hospitality Pvt. Ltd.), was earlier issued Fire Safety Certificate by this department vide letter no-F.6/DFS/MS/EH/2023/SZ/138 dated 04/05/2023. The premises was re-inspected by the officer concerned of this department on 24/04/2026 in the presence Sh. Anchit Kapil and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy class "Group-D" "Assembly Building" (Eating House at First Floor only) and validity up to 31/03/2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 06/05/2026 at New Delhi by.


(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002.-to ensure the occupancy as detailed above & deviation if any.
2. The authorized signatory, M/s. Summer House Café (A unit of Shaktiraj Hospitality Pvt. Ltd.), located at 1st Floor & Terrace, DDA Shopping Complex, Aurobindo Palace, Hauz Khas, New Delhi-110016 (Online Portal ID No. 2026041004812 dated 10/04/2026)

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

INSPECTION REPORT				
1. Name & address of the building		M/s. Summer House Café (A unit of Shaktiraj Hospitality Pvt. Ltd.), located at 1 st Floor, DDA Shopping Complex, Aurobindo Palace, Hauz Khas, New Delhi-110016.		
2. Type of Occupancy		Assembly Building (Group-D), restaurant is running at first floor only, in a building comprised of ground and first floor only.		
3. Type of Case		Renewal		
4. Details of Previous NOC		F.6/DFS/MS/EH/2023/SZ/138 dated 04/05/2023		
5. Fire Safety directives letter No		DFS ACT-2007 & Rules 2010		
6. Date of inspection		24/04/2026		
7. Name of Inspecting Officer		Sarabjeet Singh ADO (BCP)		
8. Name and designation of officers From the building side		Anchit Kapil		
9. Year of Construction		2005-06		
10. Applicant's letter No.		Online-ID No- 2026041004812 dated 10/04/2026		
S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC/ Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1.	Access to building	06m Required	Provided	MR
N A	• Road width	NA	Directly accessible form the road	NA
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02 Nos.	02Nos.	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	Required	1.57m & 0.75m	MR(old case)
	• Upper Floor	NA	NA	NA
	• Basements			
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	02 Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	Required	1.44m	MR(old case)
3.	Compartmentation			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management system			
	a) Basements	NA	NA	NA
	b) Upper floors	Required	Provided in kitchen	MR(old case)
5.	Fire Extinguishers			
	a) Total numbers	14 Nos.	14Nos. Provided	MR
	b) Types	ABC/CO ₂	ABC-10 & CO ₂ -04	MR

7/11

	c) IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			MR
	a) Total numbers on each floor	01 Nos.	Provided	MR
	b) Length of hose reel hose	30m	Provided	MR
	c) Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			MR
	a) Type of detectors	Required	Heat & Smoke	MR
	b) Location of Main Panel	Required	Provided	MR
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			NA
	a) Basement	NA	NA	NA
	b) Ground & Upper Floors	Required	Provided in rest.	MR
	c) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			MR
	a) Size of riser/down-comer	Required	100mm Provided	MR
	b) Number of hydrants per floor	Required	01 Provided	MR
	c) Hose Box	Required	01 Provided	MR
12.	Yard Hydrants			NA
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	Pumping Arrangements			NA
	• Ground Level			NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			MR
	➤ Discharge of pump	450LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs	10,000ltrs	MR(old case)


n/22

Exit Signage.		Required	Provided	MR
Provision of Lifts.				
a)	Pressurization of Lift Shaft	NA	NA	NA
b)	Pressurization of Lift lobby	NA	NA	NA
c)	Communication In lift Car	NA	NA	NA
d)	Fireman's Grounding Switch	NA	NA	NA
e)	Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18. Refuge Area.				
a)	Total Area	NA	NA	NA
b)	Location	NA	NA	NA
19.	Fire Control Room			
a)	Detector System Panel	NA	NA	NA
b)	Flow Switch Panel	NA	NA	NA
c)	PA System Panel	NA	NA	NA
d)	Battery backup	NA	NA	NA
e)	Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	One Co2, type fire extinguishers provided near electric panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. Earlier shortcomings issued by this department vide letter No. F.6/DFS/MS/FH/2026/301 dated 09/04/2026 have been rectified.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter F.6/DFS/MS/EH/2023/SZ/138 dated 04/05/2023, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended. Accordingly, DFA is put up for approval and signatures please.

Last Date of Disposal :- 09/04/2026.


 Name - Sarabjeet Singh
 Designation - ADO(BCP)

DO (SD)


 29/4/26
Ravinder Singh

CF-154


 29/4/26
A.K. MALIK

Principal Director

DO (SD)


 4/5/26
A.K. MALIK

CF-154


 29/4/26