



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आपत्ती का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 749

Dated: 23/09 /2025

To,

The Principal,
Sunder Public Middle School,
C-6, Yamuna Vihar, Delhi-53.

Subject: - Regarding grant of Fire Safety Certificate in r/o Sunder Public Middle School located at
C-6, Yamuna Vihar, Delhi-53.

Sir,

This has a reference to your Outdoor Dairy No. 5392 dated 28/08/2025 on the subject cited above. In this connection, it is to inform you that school was inspected by the officer concerned of this department on 09/09/2025 in the presence of Mr. Shobha Ram and observed that school building comprised of Basement, Ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. Fire extinguisher found empty.
2. First-Aid-Hose Reel provided but found not functional.
3. Fire pump of capacity 220 LPM provided against the requirement of 450 LPM.
4. Overhead tank capacity of 10,000 liters found removed.
5. Exit & floors Signage's found removed in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

You're faithfully,


19/9/2025

VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. Director of Education, GNCT of Delhi, Old Secretariat, Civil Lines, Delhi-110054.
2. The Principal, Sunder Public Middle School, C-6, Yamuna Vihar, Delhi-53