



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 344

Dated: - 22/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. S.P.M. Civic Centre, JL Nehru Marg,
New Delhi -110002.

Sub.: - Regarding renewal of Fire Safety Certificate in respect M/s Sunrise Marriage And Party Hall, located at A-1, Dheerpur, Opposite Radha Swami Satsang Near Nirankari Colony, Delhi-110009.

Sir,

This has reference to online application no. 2026032103285 dated 23/03/2026 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officers concerned of this department on 07/04/2026 in the presence of Sh. Mayank Gupta (Manager) During inspection, it was observed that the above said banquet hall is comprised of ground + 01 upper floor only. After inspection, the following shortcomings were observed: -

1. Two staircases varying from 1.40 to 2.0 m & 1.20 to 1.30 m are provided against required of 2.0 m & 1.50 m.
2. Fire check door found removed.
3. Overhead water storage tank capacity of 20,000 ltrs. is provided against the required capacity of 25,000 ltrs.
4. Exit signages found removed.
5. Standby power supply found removed.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage & **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

21/04/26

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Authorized Signatory, M/s Sunrise Marriage And Party hall, located at A-1, Dheerpur, Opposite Radha Swami Satsang Near Nirankari Colony, Delhi-110009.