

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/Indl./2025/SZ/ 80

Dated : 18/02/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s Supreme Impex** Situated at D-6/5, Okhla, Industrial Area, Phase-II, New Delhi -110020 is comprised of Basement, Ground Plus Two upper floors owned/occupied by M/s Supreme Impex was issued FSC by this department vide letter no F6/DFS/MS/Indl/SZ/2022/112 Dated 14/03/2022. The premise was re- inspected by the officer concerned of this department on 06/02/2025 in the presence of Mr. K A Lal and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and found that the said building / premises is fit for occupancy class **Group G "Industrial Building"** with effect from 18/02/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/02/2025 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:

1. The Auth. Signatory, Supreme Impex, Situated at D-6/5, Okhla, Industrial Area, Phase-II, New Delhi -110020.
2. The Executive Engineer (Bld Department), MCD, Jal Vihar, Lajpat Nagar, New Delhi-110024.

**Conditions for the validity of the safety certificate:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
2. The trained staff should be available round the clock.
3. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
4. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
5. Basement shall be used strictly as per Building Bye Laws.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



## INSPECTION REPORT

1	Name & Address of the Building	M/s Supreme Impex, located at D-6/5, Okhla Industrial Area, Ph- II, New Delhi -110020		
2	Type of Occupancy	Industrial Building G		
3	Building Comprised of	Basement + Ground + Two Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Industrial/SZ/2018/2149 dated 05/10/2018 & F6/DFS/MS/Indl/SZ/2022/112 Dated 14/03/2022		
6	Fire Safety Directives Letter No	F6/DFS/MS/2007/2376 dated 27/08/2007 F6/DFS/MS/BP/2015/504 Dated 11/03/2015		
7	Date of Inspection	06/02/2025		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. K. A Lal		
10	Year of construction	2005 & 2015		
11	Applicant letter No.	Outdoor diary no 11951 Dated 29/01/2025		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	12 mtr	Provided	MR
	• Gate width	4.5 mtr	About on road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	1. Upper floors	2 No's	Provided	MR
	2. Basement floor	2 No's	Provided	MR
	b. Width of Staircase			
	1. Upper floors	1.50 m each	1.50 mtr & 1.50 mtr	MR
	2. Basement floor	1.50 m each	1.50 mtr & 1.50 mtr	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	02	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.25 m	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	12 ACPH	Exhaust Fan	M/R
	• Upper floors	12 ACPH	Natural ventilation	M/R
5.	Fire Extinguishers			
	• Total numbers	30	Provided	MR
	• Types	ABC / Co2	Provided	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01 at each floor	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR



7	<b>Automatic Fire Detection &amp; Alarming System.</b>			
	• Type of detectors	Required	Heat & Smoke	MR
	• Location of Main Panel	Required	Provided at GF	MR
	• Location of Repeater Panel	NA	N/A	NA
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	All area	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper floors (on 2 <sup>nd</sup> floor)	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	• Size of Riser / Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	01	Provided	MR
	• Hose box.	01	Provided	MR
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	03	Provided	MR
	• Hose box.	03	Provided	MR
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	2280 LPM	Provided	MR
	➤ Head of main pump.	60 m	Provided	MR
	➤ Number of main pumps.	01	Provided	MR
	➤ Jockey Pump output.	180 LPM	Provided	MR
	➤ Jockey Pump head.	60m	Provided	MR
	➤ Standby Pump output.	2280 LPM	Provided	MR
	➤ Standby Pump head.	60 m	Provided	MR
	➤ Auto Starting / Manual Stopping.	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	900 LPM	900 & 180 LPM	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity.	75000 ltrs	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	20,000 Ltrs	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17.	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19.	<b>Fire Control Room.</b>			

	<ul style="list-style-type: none"> <li>• Detector System Panel.</li> <li>• Flow Switch Panel.</li> <li>• PA system Panel.</li> <li>• Battery backup</li> <li>• Building floor plan</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	DCP extinguishers provided near electric panel	MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Indl/SZ/2022/112 Dated 14/03/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.



Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Designation: ADO (BCP)

DO (SD)

*Mukherjee*

*Chd/MS*

*13/04/2025*

*Director*

*17/04/25*

*AD/1/1*

As approved, F.T. letter is  
forwarded for your signature

*Pl*

*1/11/24*

*Director*