

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2025/ 390

Dated: 29/07/2025

FIRE SAFETY CERTIFICATE

Certified that Block- A, B + C + D + E + F, Additional Office Complex at Supreme Court of India, Near Pragati Maidan, New Delhi, comprised of Block- B + D + E - 3 Basement + Ground + 08 upper floors, Block- A& C- 3 Basement + Ground + 05 upper floors & Auditorium , Block - F, 3 basement + ground + 03 upper floors, was earlier granted FSC vide letter No. F6/DFS/MS/NDZ/2022/188 dated 29/04/2022. Now, the premises was re-inspected by the officers concerned of this department on 11/07/2025 in the presence of Sh. S.P. Pandey (JE) and found that the said building block has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Business Building** with effect from 29/07/2025 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/07/2025 at New Delhi by.


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Registrar , Supreme Court of India , New Delhi
2. The Executive Engineer & Senior Manager (E), Supreme Court Project, Electrical Division-II, CPWD, Gate No. 9, Pragati Maidan, New Delhi - 110001.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction, electrical installation, set back area etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration shall strictly prohibited. and if used same shall be of 02 hr fire rating.