



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/ECN/2026/ 282

Dated: 09 /07 /2026

To,

Sh. Rajiv Sharma, (Estate Manager),
Surya Kiran Maintenance Society,
Surya Kiran Building, 19, K.G Marg,
New Delhi 110001.

Sub: Application for renewal of Fire Safety Certificate in r/o of Surya Kiran Building, 19, K.G Marg, New Delhi - 110001.

Sir,

Please refer your Online DFS Portal ID: 5202631701675 dated 17.03.2026, on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officers concerned of this department on 22/05/2026 in the presence of Sh. Shyam, Fireman and following shortcomings were observed: -

1. Fire Check Door found removed from staircases at some locations.
2. Manually Operated Electronic Fire Alarm (MOEFA) provided but found non-functional in basement.
3. Smoke Management System provided but found non-functional in basementp.
4. Automatic detection system found removed at some places.
5. One hose reel found removed at 13th floor.
6. Underground water storage tank provided 1,30,000 Ltrs against the required capacity of 2,00,000 Ltrs.

In view of the above shortcomings, the application for renewal of fire safety certificate cannot be considered at this stage & stands **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy To: -

1. The Chairman, NDMC, Palika Kendra, Sansad Marg, New Delhi - 110001.