

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2025/ 145

Dated: 11/02/2025

**FIRE SAFETY CERTIFICATE**

Certified that Certified that **Sushila Deevi Public School, B-68, Yadav Nagar, Sameypur, Delhi -110042**, comprised of **Ground + Two Upper Floors** owned/occupied by **Sushila Deevi Public School** was issued fire safety certificate by this department vide letter no **F.6/DFS/MS/School/WZ/2020/61 dated 19.02.2020**. The premises was re-inspected by the officer concerned of this department on **29.01.2025** in the presence of **Sh. Satya Pal Singh Yadav (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the fire prevention and fire safety requirement in accordance with Rule 35(6) of Delhi fire service Rules 2010, and premise is fit for class **Educational Buildings** with effect from 11/02/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on 11/02/2025 at New Delhi by

(Atul Garg)  
**DIRECTOR**  
 Ph: 011-23414000

**Copy to:**

1. The Principal, Sushila Deevi Public School, B-68, Yadav Nagar, Sameypur, Delhi 110042.
2. The Director of Education, Old Secretariat, Delhi.

**Conditions for validity of Fire Safety Certificate;**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)



**INSPECTION REPORT**

1. Name & address of the building	Sushila Deevi Public School, B-68, Yadav Nagar, Sameypur, Delhi 110042.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (Ground + 02 upper floors)			
4. Details of Previous NOC	F.6/DFS/MS/School/WZ/2020/61 dated 19.02.2020.			
5. Fire Safety directives letter No	-NA-			
6. Date of inspection	29.01.2025			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Sh. Satya Pal Singh Yadav (Manager)			
9. Year of Construction	-NA-			
10. Applicant's letter No.	Online e-mail dated 20.01.2025.			
<b>S. No</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>Rule 35(6)</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	Required	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	01nos.	Provided	MR
	<b>e. Width of Corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door Size</b>	-NA-	-NA-	-NA-
3.	<b>Compartmentation</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	c) Basements	-NA-	-NA-	-NA-
	d) Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers</b>			
	• Total numbers	09nos.	09nos.	MR
	• Types	ABC/CO2	ABC-09nos.	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	01nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR

7.	<b>Automatic fire detection and alarming system</b>			
	f) Type of detectors	-NA-	-NA-	-NA-
	g) Location of Main Panel	-NA-	-NA-	-NA-
	h) Location of Repeater Panel	-NA-	-NA-	-NA-
	i) Alternate source of power	-NA-	-NA-	-NA-
	j) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	<b>Pumping Arrangements</b>			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-



N/12

17.	Standby power supply			
18.	Refuge Area.	-NA-	-NA-	-NA-
	➤ Total Area			
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room	-NA-	-NA-	-NA-
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 422 dated 10.07.2024, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2020/61 dated 19.02.2020, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

*Ajay*  
18/2/25

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

DO (NW)

*Ajay*  
04/02/2025

By CRO (WZ) - M/R

CRO *Khush*  
6/2/2025

Director *My*  
7/2/25

*Ajay*

Fi letter to put up for kind perusal  
and signature please.

Director *My*  
14/2/25

*Ajay*  
18/2/25

CFO/... 987.1111.  
Dated... 6/2/2025