

 **GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

2/83
संख्या
दिनांक

No: F.6/DFS/MS/2025/WZ/ 449

Dated: 10/09/2025

To,

Sh. Ajit Singh,
Sushila Hospital,
Safiabad Road, Narela,
Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Sushila Hospital located at Safiabad Road, Narela, Delhi- 110040.

Sir,



This has reference to your letter no. nil dated 06/06/2025 received through outdoor diary no. 2540 date 09/06/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said Hospital building has been carried out by officers concerned of this department on 14.07.2025 to see the compliance of the requisite fire safety measures. Sh. Ajit Singh was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground & 04 upper floors. Your request for issuance of FSC is rejected as the following shortcomings were observed:

1. Fire check door not provided at some places.
2. Pressurization of staircase and lift lobby found not provided.
3. Shafts are not sealed at each level.
4. Electrical shafts are not segregated with fire/ smoke check door.
5. First aid hose reels found provided but not functional.
6. Detectors are not provided at some places.
7. Sprinklers are not provided at some places.
8. Internal hydrant found provided but not functional.
9. Yard hydrant found not provided.
10. Pumping system found provided but not functional.
11. UG tank found empty.
12. Draw off connection is not provided near U.G. tank.
13. Floor level signage and exit signage are not provided at some places.

Keeping in view of above shortcomings, Fire Safety Certificate is not considered at this stage and rejected. You are advised to rectify the above-mentioned shortcomings for further consideration in this matter. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours Faithfully


8/9/2025
(Virendra Singh)
Chief Fire Officer


Copy to:-

1. The Medical Superintendent- Nursing Home, Govt. of NCT, Delhi, Directorate General of Health Services, Nursing Home Cell, 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi- 110092.