

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI- 110001

No. F.6/DFS/MS/GH/2025/SZ/ 340
To

Dated: 04./08./2025

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049

Sub:-Regarding renewal of FSC in r/o M/s Suvidha Deluxe Guest House located at
3335 to 3337, Hari Mandir, Pahar Ganj, New Delhi

Sir,

This is in reference with **MCD Portal ID 2025070811090 dated 08/07/2025** on the subject cited above. In this connection, it is inform you that the premises have been inspected by officer concerned of this department on 17/07/2025 in the presence of Md. Rizvan (Manager) of the Guest House. During the inspection, it was observed that the guest house is running at Ground plus 04 upper floors. The shortcomings observed are as below;

1. The occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL 2016.
2. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


21/8/2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. MCD Portal ID 2025070811090 dated 08/07/2025 for uploading.