

CH

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/293

Dated: 17/06/2025

To

The Joint Commissioner of Police,
Licensing Unit, First Floor,
Police Station Defence Colony,
New Delhi-110049

Sub: Inspection report from fire & life safety point of view in r/o M/s Suvidha Deluxe Guest House at 3335 to 3337, Hari Mandir Marg, Pahar Ganj, New Delhi -110055

Sir,

Please refer to online portal (etl.mcdonline.nic.in) application No. 2025052609149 dated 26/05/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 09/06/2025 in the presence of Manager of the Guest House. During course of inspection, the shortcomings observed are as below.

1. Terrace level fire pump found provided but not automatic in operation.
2. Overhead water tank exclusive for firefighting found tapped for domestic purpose.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Authorized Signatory, M/s Suvidha Deluxe Guest House at 3335 to 3337, Hari Mandir Marg, Pahar Ganj, New Delhi-110055