

C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.


No. F.6/DFS/MS/School/2025/SZ/1189

Dated: 25/9/25

FIRE SAFETY CERTIFICATE

Certified that the S.V. Public School running at ground floor only in a building comprised of ground plus one upper floor located at B-1 Block, Dass Garden, Baprola Vihar, Najafgarh, New Delhi-110043, owned/occupied by Saraswati Vikas Parishad Educational & Welfare Society (Regd.) was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2022/SZ/627 dated 10.06.2022. The school building was re- inspected by the officer concerned of this department on dated 18.09.2025 in the presence of Sh. Pawan Bhardwaj (Manager) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Director of Education and that the building/ premises (ground floor only) is fit for occupancy class "Educational Building" w.e.f. 25/9/25 for a period of three years, subject to compliance of the conditions printed as under.

Issued on 25/9/25 at New Delhi by.


25/9/25
(Virendra Singh)
Chief Fire Officer
90%

Copy to: -

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.
2. The Manager, S.V. Public School, B-1 Block, Dass Garden, Baprola Vihar, Najafgarh, New Delhi-110043.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/13

INSPECTION REPORT

1. Name & address of the building : S.V. Public School, B-1 Block, Dass Garden, Baprola Vihar, Najafgarh, New Delhi-110043.
2. Building comprised of : G+1, but school running at ground floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/627 dated 10.06.2022
6. Fire Safety directives letter No : Circular No. 3298 to 3398 dated 01.03.2011
7. Date of inspection : 18.09.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Pawan Bhardwaj (Manager)
10. Year of Construction : 2000
11. Applicant's letter No. : S.V.-2025/26-02 dated 18.09.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 10.06.2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none">Road widthGate widthWidth of internal road	Accessible N/A N/A	05 m N/A N/A	M/R, old case N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	School running at ground floor only		
	<ul style="list-style-type: none">Upper Floors	N/A	N/A	N/A
	<ul style="list-style-type: none">Basements	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none">Upper Floor	N/A	N/A	N/A
	<ul style="list-style-type: none">Basements	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none">Fire check door	N/A	N/A	N/A
	<ul style="list-style-type: none">Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size			
		Old case	.85/.95 m	M/R, old case
3.	Compartmentation			
	<ul style="list-style-type: none">Fire check doorSealing of electrical shaftsFire Rating of shaft doorWater CurtainFire Dampers	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none">BasementsUpper floors	N/A N/A	N/A N/A	N/A N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none">Total numbersTypesIS marking	02 no's ABC/CO ₂ type ISI marked	Provided	M/R
			Provided	M/R
			ISI marked	M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none">Total numbers on each floorLength of hose reel hoseNozzle diameter	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A

N/19

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
		(No Lift)		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A

MIS

18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note:- As per undertaking submitted by the Manager (placed at C- 73) SV Public School is comprised of ground plus one upper floor but school is running at ground floor only and having two rooms on first floor for guard residence.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2022/SZ/627 dated 10.06.2022, is recommended to be renewed in accordance to the Circular No. F.16/Estate/CC/Fire-Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

Signature of Inspecting Officer
Name:- R.K. Yadav
Designation:- ADO (JKP)

DO (SW)

20/9/22

CFO

22/9/2022

Principal Director

CFO to Jammu

22/9/22

CFO

23/9/2022

ADO (JKP)

P.T.O