

2/11/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 15

Dated: 07/01/2025

To,
The Manager,
M/s Swagat Palace Guest House,
Flat 2- 3, D.B.G. Market, Karol Bagh,
New Delhi.

Sub: Non compliance of gazette notification in r/o M/s Swagat Palace Guest House located at Flat 2- 3, D.B.G. Market, Karol Bagh, New Delhi.

Sir,

This has reference to on line ID No. 2024062409858 dated 09/12/24 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 02/01/25 in the presence of Mr. Rajesh and following shortcomings were observed: -

1. CO - detectors found nonfunctional.
2. Stand by power supply not provided.
3. Further, the complete set of building plans with duly signed by the architect and owner itself is not upload on the portal.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of police (Lic.), 1st Floor, Defense Colony Police Station , New Delhi.