




No. F6/DFS/MS/School/SZ/2025/1305

Dated: 11 / 11 / 2025

**FIRE SAFETY CERTIFICATE**

Certified that the Swami Sivananda Vidya Bhawan located at Sivananda Marg, Amar Colony, Lajpat Nagar-IV, New Delhi -24, building comprised of Ground floor only owned/occupied by Swami Sivananda Vidya Bhawan was earlier issued FSC vide letter No. F6/DFS/MS/School/SZ/2022/1119 dated 10/10/2022. Now, The said premises was re-inspected by the officer concerned of this department on 28/10/2025 in presence of Mrs. Rimmi Vig (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 issued by Directorate of Education and the Building (Ground floor only) is fit for occupancy of "Educational Building" (Group - B) with effect from 11 / 11 / 2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 11/11/2025 at New Delhi by.

  
(A.K. Malik)  
Dy. Chief Fire Officer  
Delhi Fire Service  
o/c w

**Copy to: -**

1. The Dy. Director of Education, GNCT of New Delhi Distt. South Block-C, Defence Colony, New Delhi- 110024.
2. The Principal, Swami Sivananda Vidya Bhawan located at Sivananda Marg, Amar Colony, Lajpat Nagar-IV, New Delhi - 110024.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

2/19  
**INSPECTION REPORT**

1	Name & address of the building	Swami Sivananda Vidya Bhawan located at Sivananda Marg, Amar Colony, Lajpat Nagar-IV, New Delhi – 110024.		
2	Building is comprised of	Ground floor only		
3	Type of occupancy	Group B - Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/SZ/2022/1119 dated 10/10/2022		
6	Fire safety directives letter no.	D.O.E Old Circular No. 262-362 dated- 17/01/2005		
7	Date of inspection	28/10.2025.		
8	Name of the inspecting officers	Y. S. Meena ADO/Mathura Road		
9	Name of the designation of officer from the building side	Mrs. Rimmi Vig (Principal)		
10	Year of construction	2000		
11	Applicant's letter no.	Outdoor Dairy No. 6418 dated 25/09/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Old Cir. dated 17/01/2005 Requirement	Provided at site	Remarks MR/N MR
1	<b>Access to Building:</b>			
A	Road width	Accessibility	Accessibility (9.0 mtrs.)	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	N/A	N/A	N/A
c	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	N/A	N/A	N/A
b	Basement	N/A	N/A	N/A
C	Protection of exits		N/A	N/A
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no.	N/A	N/A
E	Width of corridor	1.50 mtrs.	1.50 mtrs.	MR
F	Door size	1.0 mtr.	1.0 mtr. (class room)	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A



5. Fire Extinguisher:					
	A	Total numbers	04 nos.	05 nos.	MR
	B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
6 First-Aid-Hose Reel:					
	A	Total numbers of each floor	N/A	N/A	N/A
	B	Length of hose reel hose	N/A	N/A	N/A
	C	Nozzle diameter	N/A	N/A	N/A
7 Automatic Fire Detection and Alarming System:					
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10 Automatic Sprinkler System:					
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:					
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:					
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:					
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	N/A	N/A	N/A
	B	Head of the pump	N/A	N/A	N/A
	C	Power supply	N/A	N/A	N/A
	D	Auto starting of pump	N/A	N/A	N/A



14	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	N/A	N/A	N/A
15	<b>Exit Signage:</b>		Required	Provided
16	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	<b>Standby Power Supply:</b>			
18	<b>Refuge Area:</b>			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	<b>Fire Control Room:</b>			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/SZ/2022/1119 dated 10/10/2022, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer  
Name Yashwant Singh Meena  
Designation ADO/Mathura Road

D.O/SD

*[Signature]*  
29/11/25

*[Signature]*  
4/11/25  
A.K. MALIK  
Principal Director

*[Signature]*  
By. Cfo (SZ)

By. Cfo to Issue.  
*[Signature]*  
24/11/25