

c-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/School/WZ/2025/ 684

Dated: 22/08/21

To,

The Principal,
Swami Sivananda Memorial Secondary & Primary School,
31, East Avenue Road, East Punjabi Bagh,
New Delhi-110026.

Sub: Regarding issuance of Fire Safety Certificate in r/o Swami Sivananda Memorial Primary School & Swami Sivananda Memorial Secondary School located at 31, East Avenue Road, East Punjabi Bagh, New Delhi-110026.

Sir,

This is in reference to your letter No. SSMPS/33/2025-2026 04/07/2025 & SSMSS/2025/1952 dated 04/07/2025, on the subject cited above. In this connection, it is to inform you that the school building was inspected by the officer concerned of this department on 05/08/2025 in the presence of Sh. Jaspal (Admin) to check the fire safety arrangements provided in the building.


During Inspection it has been observed that the said school is running in two blocks in same premises (one Primary block & one Senior secondary block) are connected with each other at each floor, comprised of ground + 02 upper floors. Fire safety arrangements such as fire extinguisher, etc are provided. **However the following Shortcomings were observed.**

1. First Aid Hose reels are not provided.
2. Terrace level Fire Pump capacity of 450LPM is not provided.
3. Over head water storage tank capacity of 10,000 ltrs is not provided.
4. Exit Signage are not provided.

In view of above Shortcomings, **the application for issuance of fire safety certificate is not considered at this stage & rejected.** The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours Faithfully,


Virendra Singh
Chief Fire Officer

o/c 
21/8/2025

Copy To: -

1. The Director, Directorate of Education old Secretariat, Delhi-110054.