



C-11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2025/School/ 610

Dated: 01/08/2025

To

The Principal,
Swami Vivekanand Model School
A-52, Sarai Extn., Adarsh Nagar, Delhi-33.

Sub: Regarding issuance of fire safety certificate in r/o Swami Vivekanand Model School at A-52, Sarai Extn., Adarsh Nagar, Delhi-110033.

Sir,

Please refer to your letter received through online e-mail dated 30/06/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 02/07/2025 to verify the fire safety measures issued vide NBC Part-IV/UBBL-2016 and observed that the building was comprised of ground & 02 upper floors only. At the time of inspection Smt. Parul Chauhan was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 The main gate of school building width is 2.50 against the requirement of 4.50m.
- 2 There is only 01 nos. of staircase is provided width of 1.10m against the requirement of 1.50m each and both staircases continues from ground to terrace level.
- 3 The width of corridor is 01m against the requirement of 1.50m
- 4 The all classrooms door size is 01m against the requirement of 1.20m.
- 5 Hose reel hose is not provided.
- 6 Terrace level fire fighting pump capacity of 450lpm is not provided.
- 7 Terrace level fire water tank capacity of 10,000ltrs for firefighting is not provided.
- 8 Standby power supply is not provided.
- 9 As built plan of the new school building shall also be submitted.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of new school building is at your own risk & responsibility.

Yours faithfully

21/08/2025
Virendra Singh
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.