



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2025/ 158

Dated: 17/03/2025

To

The Principal,  
Tagore Shiksha Niketan,  
D-91, Meethapur Extn., Badarpur,  
New Delhi-24.

**Sub:-** Regarding renewal of Fire Safety Certificate in respect of **Tagore Shiksha Niketan** located at **D-91, Meethapur Extn., Badarpur, New Delhi-24.**

Sir,

With reference to the letter bearing outdoor diary no. 12676 dated 19.02.2025 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 11.03.2025 in the presence of Mr. Hemant Kaushik (Manager) and following shortcomings were observed during the inspection.

1. Alternate staircase of width 1.50 meters has not been provided.
2. Hose reel found non functional.
3. Fire pump found non functional.
4. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
5. Exit signage has not been provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.