

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/253

Dated: 18/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **Tagore Vidya Niketan** Situated at 203, Village Rajpur Khurd, New Delhi 110068 comprised of Ground + Two Upper Floors, **but School running at ground and first floor only** owned/occupied by Tagore Vidya Niketan was issued FSC by this department vide letter No. F6/MS/DFS/School/2022/SZ/220 Dated 28/02/2022. The said premise was re-inspected by officer concerned of this department on 11/03/2025 in presence of Mr. Manoj Kumar Chaudhary (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building is fit for occupancy class **"Educational Building Group - B" (For Ground and First Floor only)** with effect from 18/03/2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued 18/03/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Tagore Vidya Niketan Situated at 203, Village Rajpur Khurd, New Delhi 110068.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

4/12

INSPECTION REPORT

1	Name & Address of the Building	Tagore Vidya Niketan Situated at 203, Village Rajpur Khurd, New Delhi 110068		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + 02 upper floors. (second floor totally tin shed & not in use)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2022/SZ/220 Dated 28-02-2022		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	11/03/2025		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Manoj Kumar Chaudhary (Principal)		
10	Year of construction	2006 School running at 2 nd & 3 rd Floor only		
11	Applicant letter No.	Outdoor diary no 14101 dated 05/03/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6 mtr	At distance of 2 length hose from road of 6 mtr	Old case
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	02 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	02 stair ways	0.70m & 0.75m	MR old case
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH	-NA-	-NA-
		12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required	04 Nos	MR
		ABC / CO2	ABC & CO2	MR
		ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	01 nos each	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7.	Automatic fire detection & alarming system.			

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of Hydrant per floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Head of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of main pumps. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Jockey Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Jockey Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Standby Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Standby Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Auto Starting/Manual Stopping. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pump house access. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. 	220 LPM	Provided	MR
	<ul style="list-style-type: none"> Head of pump. 	40 m	Provided	MR
	<ul style="list-style-type: none"> Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump. 	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Draw-off connection. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Service Inlet. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Access to tank. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Overhead tank capacity. 	2,500 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication in lift car. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's switch. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Lift signage. 	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location 	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Flow switch panel. 	-NA-	-NA-	-NA-

N/14

	<ul style="list-style-type: none"> PA system panel. Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

20. **Special Fire Protection System for the Protection of special Risk, if any.**

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/School/2022/SZ/220 Dated 28/02/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

[Handwritten signature]
12/3/25

CFO (MS)

[Handwritten signature]
13/3/2025

Director

[Handwritten signature]
13/09/24

[Handwritten signature]
AOD

As approved, F.T. letter is put up for
your signature P1

Director

[Handwritten signature]

[Handwritten signature]
13/3/25