



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001



Dated: 27/01/2025

No. F.6/DFS/MS/EH/2025/NDZ/ 31

**FIRE SAFETY CERTIFICATE**

Certified that the Tamasha (A Unit of Wholesome Nutrition LLP) located at 28 A, GF, FF, K.G Marg, New Delhi-110001, comprised of ground plus one upper floor, restaurant at ground & 1<sup>st</sup> floor, owned/occupied by Tamasha (A Unit of Wholesome Nutrition LLP) was earlier granted FSC by this department vide letter No. F.6/DFS/MS/EH/NDZ/2022/34 dated 11/02/2022. The premise was re-inspected by the officer concerned of this department on 20/01/2025 in the presence of Mr. Sanjay (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class "Assembly, Group-D" (Restaurant at ground & first floor only) with effect from 27/01/2025 and valid up to 31/03/2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on..... 27/01/2025 .....at New Delhi by

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

To:-

1. The Addl. Commissioner (Lic.)  
1<sup>st</sup> floor Police Station Defence Colony, New Delhi
2. The Medical Officer of Health, Health Department, Palika Kendra, New Delhi.
3. The Manager,  
M/s Tamasha (A Unit of Wholesome Nutrition LLP) located at 28 A, GF, FF, K.G Marg, New Delhi-110001

**MCD ID No. 2024040504317, Dated- 11/01/2025**

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The basement shall be used as per the provisions of BBL/NBC Part-IV.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



1. Name & address of the building : Tamasha (A Unit of Wholesome Nutrition LLP)  
At 28 A, GF, FF, K.G Marg, New Delhi
2. Building is comprised of : Ground plus one upper Floor only
3. Type of Occupancy : Assembly building
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/EH/NDZ/2022/34 dated 11/02/2022
6. Fire Safety directive letter No : Nil
7. Date of Inspection : 20/01/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Sanjay (Manager)
10. Year of Construction : Old Heritage Bldg.
11. Applicant's letter No : ID No. 2025011100408, Dated- 11/01/2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement /Existing fire safety arrangement	Provided at Site	Remarks MR/NMR
01	Access to Building			MR
	• Road width	09 mtr.	13 mtr.	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 nos.	02 nos.	MR
	• Upper floor	N/A	N/A	N/A
	• Basement			
	B. Width of Staircases	1.25 mtr.	0.86 mtr. & 1.36 mtr.	MR
	• Upper floor	N/A	N/A	N/A
	• Basement			
	c. Protection of Exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	1.90 mtr, 1.90 mtr & 02 mtr.	MR (old case)
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	12 ACPH	Exhaust fan	MR
05.	Fire Extinguishers			
	• Total numbers	04 nos.	08 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	Required	Provided	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos	01 nos	MR
		30 mtr	30 mtr	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of main panel</li> <li>Location of repeater panel</li> <li>Alternate source of power</li> <li>Hooter</li> </ul>	N/A	Provided	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>upper floor</li> <li>sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose box</li> </ul>	100 mm	100 mm	MR
		01 nos.	01 nos.	MR
		01 nos.	01 nos.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby pump out put</li> <li>Standby pump head</li> <li>Auto starting /manual stopping</li> <li>Pump house access</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	450 lpm	450 lpm	MR
		30 mtr	30 mtr	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 ltr.	10,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR



16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule. The FSC issued vide letter no. F.6/DFS/MS/EH/NDZ/2022/34 dated 11/02/2022 renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended.

*Deepak*  
21/01/2025  
Signature of the Inspecting Officer  
Name : Deepak Kumar  
Designation : ADO (Shd)

DO (CD)

*Rel*  
21/1/25

Dy. C.F.O (NDZ) - on leave

C.F.O.  
22/01/2025

Director

*Out CP*

*Rel*  
22/1

100 - 1000