



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/2026/SZ/ 168

Dated: 05/05/2026

To

The MS – Nursing Home,
Govt. of NCT of Delhi,
DGHS (Nursing Home Cell),
3rd Floor, Delhi Govt. Dispensary Building,
S-1, School Block, Shakarpur,
New Delhi-110092

Sub: **Inspection report from fire safety point of view in r/o M/s Tarak Hospital India Pvt. Ltd situated at C-7, Jai Bharat Enclave, Dwarka More, Opp. Metro Pillar No. 789, New Delhi-110059**


Sir,

This is with reference to this department office order No. F.6/DFS/HQ/2026/494 dated 20/03/2026, regarding inspections of the hospitals building to verify compliance of fire protection measures. In this connection, it is to inform you that the said hospital building was issued notice on Form 'O' (Notice for Entry and Inspection) under section 33 (1) of the Act by the Nominated Authority of this department and premise inspected on dated 10.04.2026 in the presence of Dr. Munish Kr. Arora (MS) of the hospital. The shortcomings observed during the inspection were recorded and issued on Form 'P' (Notice for carrying out the directions of the Nominated Authority) under section 34 (1)/43(2) of the Act. The hospital building was found non-compliant from fire safety point of view due to the following shortcomings.

1. Front lift found in use despite submitting an undertaking regarding keeping it closed permanently.
2. Hose-reel hose found non-functional at terrace.
3. Kitchen found functional at 4th floor, using LPG cylinder.
4. Escape route/corridor at 1st floor found encroached.
5. Some of the detectors found non-functional.
6. Dimensions of the underground water storage tank to be provided from a registered architect.

In view of the above non-compliance, the Fire Safety Certificate of the hospital building issued by this department vide letter No. F6/DFS/MS/Hospital/SZ/2023/182 dated 15/04/2025 remain deemed suspended till the compliance of the shortcomings. **you are requested to take necessary action at your end.**

Yours faithfully,


(A.K. Malik)
Chief Fire Officer (SZ)
Delhi Fire Service


Copy to: -

1. The Executive Engineer (Bldg.), Municipal Corporation of Delhi, West Zone, Dr. Sahib Singh Verma Nigam Bhawan, Shivaji Enclave, New Delhi-110027
2. Dr. Munish Kr. Arora (MS), M/s Tarak Hospital India Pvt. Ltd situated at C-7, Jai Bharat Enclave, Dwarka More, Opp. Metro Pillar No. 789, New Delhi-110059