



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-117
7/5
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/BNQT/NDZ/2026/ 463

Dated: 12/05/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Tarang Banquet MM located at Ground + One Upper floor of Property No. A 9/136, Road no. 56, Ghazipur, Delhi-96, was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/NDZ/2023/01 dated 06/01/2023 for Ground floor only in a building comprised of Basement + Ground + 02 upper floors. The Banquet Hall was re-inspected by officer concerned of this department on 05/05/2026 in presence of Mr. Mohit Malik (Owner of the Banquet Hall) and found that the said Banquet Hall is running at Ground + 01 upper floors of the building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. The premises/building is fit for occupancy of Group D "Assembly Building" (Banquet Hall at Ground + 01 upper floors) with effect from 12/05/2026 and valid upto 31.03.2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 12/05/2026 at New Delhi by


(Dr. S. K. Tomar)
Chief Fire Officer

Reference: etl.mcdonline application no. 2026042505772.

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, 9th floor, Civic Centre, Minto Road, New Delhi-110002.
2. The Licensee, M/s Tarang Banquet MM located at Road no. 56, Ghazipur, Delhi-96.

Conditions for the validity of Fire Safety Certificate

1. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. Basement shall be used as NBC/UBBL 2016.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhi.gov.in

INSPECTION REPORT

1.	Name and address of the building:	M/s Tarang Banquet MM located at Property no. A 9/136. Road no. 56, Ghazipur, Delhi-96.			
2.	Building is comprised of	Basement (used as store having independent exit) + Ground + 02 upper floors (Banquet Hall operational at Ground + 01 upper floor of the building)			
3.	Type of occupancy	Group D - Assembly (Banquet Hall)			
4.	Type of case:	Addition of Occupancy in existing building + Renewal			
5.	Details of previous FSC:	F6/DFS/MS/EH/NDZ/2023/01 dated 06/01/2023 for Ground floor only			
6.	Fire safety directives no.:	F6/DFS/MS/BP/2013/2135 dated 02/09/2019 for Ground floor only.			
7.	Date of inspection:	05/05/2026			
8.	Name of the inspecting officer:	Rajesh Kumar Shukla, ADO (L.N)			
9.	Name and designation of the officer from the building side:	Mr. Mohit Malik (Owner of the Banquet Hall)			
10.	Year of construction:	2008			
11.	Reference letter no.:	etl.mcdonline application no. 2026042505772.			
S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements	Provide at site	Remarks MR/NMR	
1	Access to Building:				
	A	Road width	12.0 m	40.0 m	MR
	B	Gate width	4.50 m	4.50 m	MR
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits:				
	A	No. of Staircase:			
		a) Upper floor	2 nos.	3 nos.	MR
		b) Basements	NA	NA	NA
	B	Width of the Staircase			
		a) Upper floors	1.50 m x 2nos.	2.73 m, 1.50 m to 1.80 m & 1 m	MR
		b) Basements	NA	NA (Independent Exit)	NA
	C	Protection of Exits			
		a) Fire check door	Required	Provided	MR
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace	1 no.	1 no.	MR
	E	Width of the corridor	NA	NA	NA
	F	Door size	2 m at Ground Floor. 2 m and 1.5 m at first floor.	-Doors at ground floor- 4 nos. (3.8 m, 1.75 m x 3 nos. leading to exterior open space with final exit of 2 meters) -Doors at 1 st floor- 2 nos. (3.3 m & 1.50 m)	MR
3	Compartmentation:				
	A	Fire check doors	Required	Provided	MR
	B	Sealing of horizontal & vertical opening	Required	Provided	MR
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Basements	Required	Exhaust fans	MR
	B	Upper floor	Required	Natural	MR

5	Fire Extinguishers:		10 nos.	12 nos.	MR
	A	Total numbers	ABC +CO ₂	ABC +CO ₂	MR
	B	Types	ISI marked	ISI marked	MR
	C	ISI marking			
6	First Aid Hose Reel:		01 no.	2 nos.	MR
	A	Total no. at each floor	30 m	Provided	MR
	B	Length of hose reel	5 mm	Provided	MR
	C	Nozzle diameter			
7	Automatic Fire Detection and Alarm System (ADAS):		Heat/Smoke	Provided	MR
	A	Type of detectors	Required	Provided	MR
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	Required	Provided	MR
	D	Alternate power source	Audible in entire building	Provided	MR
	E	Hooter's location	Required	Provided	MR
8	MOEFA:		NA	NA	NA
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:		NA	NA	NA
	A	Basement	NA	Provided	NA
	B	Ground floor & upper floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants:		100 mm	100 mm	MR
	A	Size of down comer	01 nos.	01 nos.	MR
	B	No. of hydrants per floor	01 nos.	01 nos.	MR
	C	Hose box			
12	Yard Hydrants:		NA	NA	NA
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements:				
	A	Ground Level			
		a) Discharge & head of main pump	NA	NA	NA
		b) Number of main pump	NA	NA	NA
		c) Discharge & head of jockey pump	NA	NA	NA
		d) Discharge & head of standby pump	NA	NA	NA
		e) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	1620 LPM	1620 LPM + 450 LPM	MR
		b) Head of terrace pump	40 m	40 m	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Auto	Provided	MR
14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	20,000 Ltrs	20,000 Ltrs	MR
15	Exit Signage:		Required	Provided	MR
16	Provision of lift:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	Required	Provided	MR
	D	Fireman switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR
17	Standby Power Supply:		Required	Provided	MR

N/45

M/s Tarang Banquet MM located at Road no. 56, Ghazipur, Delhi-96.

18	Refuge Area:			
	A	location	NA	NA
	B	Total area	NA	NA
19	Fire Control Room:			
	A	Fire detection system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	P a system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plan	NA	NA
20	Special Fire Protection for special risk if any			NA
	A	Special Fire Protection system for Protection of Special Risk, if any:		

LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Not Provided (NP) Provide but Not Functional (PNF).

Note: The previous Fire Safety Certificate has been issued to the Banquet Hall by this department vide letter no. F6/DFS/MS/EH/NDZ/2023/01 dated 06/01/2023 for Ground floor only in a building comprised of Basement + Ground + 02 upper floors. The applicant has now applied for Banquet Hall operational at Ground + 1 upper floor (existing structure as per N/1, 2). The approx. covered area of the Hall at 1st floor as per the submitted plan is 267 Sq. meters. Existing Fire Safety arrangements have been extended to the 1st Floor hall also and meet the statutory requirements.

As per the Office Order bearing letter no. F2/DFS/HQ/2024/376 dated 23.04.2024 (Copy placed at C-106), new guidelines are not required for occupancy in existing building hence compliance to letter dated 22.01.2026 (at C-98) is not mandatory.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

If agreed to the note above & in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC recommended to be issued under Rule 35 of the Delhi Fire Service Rules 2010. The last date of disposal of this application is 24/05/2026.

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (L.N)

DO (East)

CFO (NDZ)

Principal Director

FSC is put up as approved

CFO (NDZ)

11/05/26 A. correct F.P.