



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001



No. F6/DFS/MS/GH/2026/NDZ/ **748**

Dated: **13/10/2026**

FIRE SAFETY CERTIFICATE

Certified that the M/s Tarang Guest House located at Plot No. A9/136, 2nd Floor, Road No. 56, Gazipur, Delhi-110096, comprised of Basement + Ground plus two upper floors but Guest house running at 2nd floor only, Total 17 guest rooms) owned/occupied by M/s Tarang Guest House was issued FSC vide letter No.: F6/DFS/MS/2020/GH/NDZ/134 dated 10/09/2020. The premises was re-inspected by the officer concerned of this department on dated 02/09/2026 in the presence of Sh. Vijay Malik, and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Class "Residential" Group A (Guest House) with effect from **13/10/2026** for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on **13/10/2026** at New Delhi by

12/10/26

(Dr. S. K. TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

To: -

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
2. The Owner, M/s Tarang Guest House at Plot No. A9/136, 2nd Floor Road No. 56, Gazipur, Delhi-110096.
3. **MCD ID NO 2026082010590**

Conditions for the validity of Fire Safety Certificate: -

1. The FSC is valid for 2nd floor Guest house only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : **M/s Tarang Guest House at- A9/136, 2nd Floor, Road No. 56, Gazipur, Delhi-110096.**
2. Building is comprised of : Basement Ground plus two upper floors but **Guest house running at 2nd floor only, Total 17 guest rooms)**
3. Type of Occupancy : Residential Building (Guest House)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/2020/GH/NDZ/134 dated 10/09/2020
6. Fire Safety directive letter No : NBC Part VI
7. Date of Inspection : 02/09/2026
8. Name of the Inspecting officers : Deepak Kumar, ADO (Shahadra)
9. Name and designation of Officer
from the building side : Sh. Mohit Malik, Owner
10. Year of Construction : 2008
11. Applicant's letter No : 2026082010590 dated 21/08/2026

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	12 mtr.	40 mtr.	MR
	• Gate width	4.50m	4.50m	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos.	MR
	• Basement	02 nos.	02 nos	MR
	B. Width of Staircases			
	• Upper Floor	1.50m. & .90m	1.50m. & .90m	MR
	• Basement	1.50m. & .90m	1.50m. & .90m	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 no.	01 no.	MR
	e. Width of Corridor	1.50mtr.	02 mtr	MR
	f. Door Size	01mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	10 nos.	10 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-aid-Hose Reels.			
	Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	CO	Provided	MR
	• Location of main panel	Ground floor	Provided	MR
	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Near staircase	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no	01 no	MR
	• Hose Box	01 no	01 no	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	1620 Lpm.	1620 Lpm.	MR
	➤ Head of the Pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 Ltrs.	20,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	Required	HT & LT Panel	MR

The Fire protection system provided in the building were tested and checked and found functional at the time of Inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule. The FSC was issued vide letter no. F6/DFS/MS/2020/GH/NDZ/134 dated 10/09/2020 **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Last Date 18/09/2026

Deepak
07/09/2026
Signature of the Inspecting Officer
Name : - Deepak Kumar
Designation : - A.D.O (Shahdara)

DO(ED)

DO(ED)
09/09/26

CFO (East Zone)

DO(ED)
9/9/26

Principal Director

CFO to *DO(ED)*

CFO (East Zone)

DO(ED)
5/10/26

ADOL/SAAH

pl.

F.T. letter is put up for your kind signature

CFO (East Zone)

Deepak
08/10/2026

MS Deemed Approved
25/09/26